

SECTION-I
(Notice Inviting Tender)



TRIPURA STATE ELECTRICITY CORPORATION LTD.
DEPUTY GENERAL MANAGER (MATERIALS MANAGEMENT)
ELECTRICAL STORES DIVISION
ARUNDHATINAGAR :: AGARTALA.

NO.F.17(1) / DGM (MM) / ESD / 1257 - 1302 ,

DATED : 07.08.2018 .

NOTICE INVITING COMPETITIVE BIDDING/TENDER FOR PROCUREMENT OF STORE MATERIALS UNDER DEPUTY GENERAL MANAGER (MATERIALS MANAGEMENT) PLACE AT A.D.NAGAR STORES.

1.0 INTRODUCTION

The Deputy General Manager (Materials Management), Electrical Stores Division, A.D. Nagar, Agartala, Tripura invites **Two-Parts** sealed tender on behalf of TSECL, exclusively from the **resourceful experienced manufacturer only** for supply of the following materials FOT at Electrical Stores Division, A.D. Nagar, Agartala:

Sl no	Description of item.	Earnest money	Last date & time of receiving tender	Date & time of opening of tender	Cost of Tender	Time of completion
1.	<p>Design, Manufacture, Testing at works, Supply & Transportation i/c loading & unloading of 63 KVA, BIS certified (Energy Efficiency level -2), 11 / 0.433- 0.250 KV, 3 phase, 50 Hz, Distribution Transformer conforming to IS : 1180-2014 and IS: 2026 & other relevant IS as amended latest.</p> <p>Qty = 120 nos;</p> <p>N.I.T. No = ESD / 19 / 2018-'19.</p>	Rs. 2,83,484.00	29.08.2018, up to 01-00 p.m.	29.08.2018, at 03-30 p.m.	Rs. 4,000.00	6 (six) months followed by delivery schedule in Clause no 15.5 of Section-II.

2.0 SCOPE OF WORK

Scope of work covered under this package includes engineering, design, manufacture, testing, supply, transportation F.O.T. at Electrical Stores Division A.D. Nagar, Agartala, freight & insurance, unloading & stacking of materials, until the materials are formally received by the consignee, as per approved technical specification in this tender document.

3.0 Scope of work given above is only indicative. The detailed scope has been described in the **schedule of supply of item(s)** in SECTION-V attached with this bidding document. The bidders shall quote as per the schedule at SECTION-V and any deviation taken from the STIPULATED SECTION-V, their offers shall not be evaluated and rejected outright without showing any reasons thereof.

4.0 The two part tender consists the following:-

- A) Part – I : Pre-qualification & Techno-Commercial Bid.
- B) Part –II : Price Bid.

4.A) Part-I : Pre-qualification & Techno-Commercial Bid:-

The proposal of **Pre-qualification part**, shall consisting of the following documents in sealed envelope :-

4.A.i.	<ul style="list-style-type: none">● E.M.D. in the form of D.D. @ 2.0 % subject to Maximum of Rs. 5,00,000.00 on any Nationalized / Scheduled Bank, payable at Agartala, in favour of the DGM(MM), Electrical Stores Division, A. D. Nagar TSECL.● The cost of the Tender Form as in Clause no 1.0 of this section which shall be deposited in the form of Demand Draft on any Nationalized / Scheduled Bank payable at Agartala in favour of the DGM(MM) Electrical Stores Division, TSECL, A.D. Nagar Agartala in a separate sealed envelope along with bid document .
4.A.ii.	Exemption certificate if applicable in case of local SSI units needs to be furnished against submission of E.M.D.
4.A.iii.	Performance certificate of 3-star or 4-star BEE labelled / BIS-level-1, 63 KVA Distribution Transformer or tendered item i.e. 63 KVA, BIS certified (label -2) against supply executed by the bidder in different reputed Power utilities at least for 25% quantity accompanied with 25% value during last 5 (five) years and running satisfactorily for more than one year shall have to be furnished along with the bid.
4.A.iv.	Photo copy of Manufacturer(s) Permanent Registration Certificate issued by the Deptt. of Industries duly attested by Govt. Officials / Notary.
4.A.v.	Photo copy of PAN Card and GSTIN Registration Certificate duly attested by Govt. Officials / Notary.
4.A.vi.	TCC of current validity shall be attached (for State base Vendors only).
4.A.vii.	Copy of balance sheet (audited by Chartered Accountant) of the bidder in support of annual turnover for the last 3 (three) years.

4.A.viii.	The Type Test certificate for - <ul style="list-style-type: none"> • (i) Short Circuit Test • (ii) Impulse Test respectively of tendered item i.e. 63 KVA, BIS certified (label -2) Distribution Transformer conforming to IS : 1180-2014 and IS : 2026 as amended latest not older than 5 (five) years as on the date of opening of the tender shall be from CPRI-Bangalore or ERDA, Vdodara. N.B. Refer to Clause no 8.0, Section II.
4.A.ix.	Following documents are to be submitted with Pre-qualification & Techno-Commercial Bid document – <ul style="list-style-type: none"> • BIS (label -2) certificate issued in favour of the manufacturer with its validity date upto minimum 6(six) months w.e.f. the date of opening of the bid and BIS logo sticker with registration no. which is to be provided on the body of the transformer; otherwise bid will be treated as non-responsive.
4.A.x.	Photo copy of eligibility certificate for getting procurement preference benefit against the SSI registered firm must be accompanied with the bid document as per norms of the state Govt. matching with TSECL purchase policy (15% w.r.t 1st lowest rate of outside bidder) for evaluation of tender on production of document / certificate issued by the Dept. of Industries, Govt. of Tripura.
4.A.xi.	The credential of the participants with reference to quality of recent / past supplies to TSECL will be considered as a criterion among others. The past performance of suppliers regarding supply of transformers to TSECL should be the guiding factor during evaluation of pre-qualification & Techno-commercial bid.
4.A.xii.	Any bidder who has been debarred / black listed by any Central (GOI) / State Govt owned Power Utility, for supply of similar materials during last 3 years for whatever reasons and thereby shall stand disqualified automatically at the very pre-qualification stage. Therefore, the Party (vendors) submitting the tender documents is liable to enclose a “Declaration” to this effect with due certification by “NOTARY” depicting full name & designation.(As per specification in Format-A).
4.A.xiii.	Detailed type tested design and drawing of the item(s) as applicable offered are to be furnished.
4.A.xiv.	Guaranteed technical particulars to be furnished as per Format appended along with the technical bid.
4.A.xv.	Information to be furnished by the tenderer/bidder for appraisal of firm’s capability & capacity to manufacture tender item as per requirement to tender enquiry Format-I (Section-IV).
4.A.xvi.	Detail of Testing Facilities at manufacturer works as per requirement to tender enquiry Format- II (Section-IV).

N.B. INCOMPLETE PARTICULARS WILL LEAD TO REJECTION OF THE BIDS.

4.B) Part-II shall be of **Price bid**, consisting of the following documents in sealed envelope :-

4.B.i.	Detailed Price Break up as per Price bidding schedule as in section -V.
4.B.ii.	Downloaded tender document in undamaged condition shall be signed by the tenderer / bidder on all pages and will be enclosed with the PRICE BIDDING SCHEDULE (as given in Section-V).
4.B.iii.	Acceptance of Validity period.
4.B.iv.	Acceptance of Delivery schedule.

Only the successfully qualified **Pre-qualification & Techno-Commercial** bidders shall be considered for opening of **Price bid**. The Price bid shall be opened with prior intimation to the successful qualified bidders only.

Bids submitted without documents as indicated above will be treated as **disqualified**.

N.B. Bidders are to fill up the check list as given below :

Check list for Pre-Qualification part of PART-I bid.

Sl. No	Particulars of Pre-qualification Bid	Confirmation against Submission (with page no) / Non-submission.
I	Submission of E.M.D.	
	Submission of Tender cost	
II	Submission of Exemption certificate (applicable for local SSI unit)	
III	Performance certificate of 3-star or 4-star BEE labelled / BIS-level-1 or 2, 63 KVA Distribution Transformer against supply executed by the bidder in different reputed Power utilities : i). at least for 25% of tendered quantity and ii). at least for 25% of tendered value	
IV	Photo copy of Manufacturer(s) Permanent Registration Certificate issued by the Dept. of Industries duly attested by Govt. Officials / Notary.	
V	Submission of PAN card & GSTIN Registration Certificate	
VI	Submission of TCC of current validity (for State based Vendors only)	
VII	Submission of Audited balance sheet for last 3(three) years	
VIII	Submission of the Type Test certificate for tendered item i.e. 63 KVA, BIS certified (label -2) (i) Short Circuit Test (ii) Impulse Test respectively as per Clause no 4.0 viii of Section I.	
IX	Submission of necessary certificate for 63 KVA distribution transformer i/c. its coloured sample leveling specification as per BIS (level-2).	

X	Submission of photo copy of eligibility certificate for getting procurement preference benefit against the SSI registered firm	
XI	Submission of the credential of the participants with reference to quality of recent / past supplies to TSECL .	
XII	Submission of Format-A, regarding non-blacklisting confirmation	

Check list for Techno-Commercial part of PART-I bid.

Sl. No	Particulars of Techno-Commercial Bid	Confirmation against Submission (with page no) / Non-submission.
1	Detailed type tested design of the item as offered with drawings which will be a part of contract to be furnished	
2	Guaranteed technical particulars to be furnished as per Format appended along with the technical bid matching with the drawing.	
3	Information to be furnished by the tenderer/bidder for appraisal of firm's capability & capacity to manufacture tender item as per requirement to tender enquiry as per Format- I of (Section-IV).	
4	Detail of Testing Facilities at manufacturer works as per requirement to tender enquiry as per Format- II of (Section-IV).	
5	Checklists are to be properly filled up & to be furnished as per Format-IV of (Section-IV).	
6	Check list for Transformer - core assembly stage	
7	Check list for Transformer - coil winding stage	
8	Check list for Transformer - core coil assembly stage	
9	Check list for Transformer - Final assembly stage	
10	Check list for Transformer - Ready for dispatch	
11	Heat dissipation calculation sheet is to be submitted by the bidder	
12	Maximum flux density and Core-Weight calculation	

Check list for Price Bid of PART-II bid.

Sl.	Particulars of Price Bid	Remarks of the manufacturer
1	Detailed Price Break up as per Price Schedule.	
2	Submission of original signed bid document.	
3	Acceptance of Validity period.	

4	Acceptance of Delivery schedule.	
---	----------------------------------	--

Bidders shall have to produce original document as and when asked by the TSECL authority for verification and authentication of documents submitted.

5.0 All the proposals shall be separately sealed with the inscription of proposal (bid) along with tender reference. The offers containing all three proposals shall be sealed in a big envelop with the NIT No. & date of opening scheduled and to be submitted within date specified and shall be opened sequentially in presence of authorized representative of intending bidders.

5.1 Tender will be received only at Electrical Stores Division, Arundhatinagar; Agartala **up to 1.00 pm**. The pre-qualification and techno-commercial bid shall be **opened at 3.30 pm** on the same day. If there happens to be a holiday declared by the State Government the pre-qualification bid shall be opened on the next working day, at the same time. **The technical bid will be opened only after finalization of the pre-qualification bid. Successful Bidder(s) in the pre-qualification segment shall only be allowed for consideration of technical bid offer. In this bid segment, the bidder has to qualify the requirement of all concerned parameters of the NIT. Only the successful bidders in this bid segment shall be allowed for opening of their Price bid offer.** Tender without earnest money (to be deposited in the form of Bank Draft on any schedule Bank payable at Agartala) shall be liable for rejection. No tender submitted or received through post after the fixed date and time.

(In case the above scheduled last date for receiving of tender against any N.I.T. is declared holiday by the State Government tender(s) in response to the said N.I.T. will be received up to 1 p.m. on the following working day keeping other clauses of N.I.T. unchanged.)

5.2 The bidder shall bear all cost and expenses associated with purchase and submission of its bid including post bid discussions, technical & other presentation etc., and TSECL will in no case be responsible or liable for those cost, regardless of the conduct or outcome of the bidding process.

5.3 The bidder shall furnish documentary evidence in support of the qualifying requirements stipulated above along with their bid. Bid received without such documents shall be summarily rejected.

5.4 Tender form can be downloaded from TSECL's official website (**URL: <http://www.tsecl.in/>**) and the cost of the Tender Form shall be as in Clause no 1.0 of this section which shall be deposited in the form of Demand Draft on any Nationalized / Scheduled Bank payable at Agartala in favour of the DGM(MM) Electrical Stores Division, TSECL, A.D. Nagar Agartala. in a separate sealed envelope along with bid document .

Non-submission / short submission of cost of tender form in case of down loading will be treated as non responsive and shall be summarily rejected.

5.5 The downloaded tender document in undamaged condition shall be signed by the tenderer/ bidder on all pages and will be enclosed with the Price bid. All corrections to rates and items in the tender should be initialed by the tenderer/bidder. Every pages of the rate schedule be signed in full by the tenderer / bidder.

5.6 The bidders must quote their rates in figures as well as in words in the prescribed price bidding schedule in the bidding document. If a schedule framed by the bidder other than the schedule in TSECL's bid documents is submitted, TSECL shall not consider bidders' offer for evaluation and it will be considered as NON-RESPONSIVE and will be rejected.

The Bidder shall have to give a DECLARATION that he / they have gone through the details of the bidding document as per format appended.

5.7 Canvassing in connection with tenders / uncalled for remarks by the tenderer will lead the tender to summery rejection.

5.8 The bidder should offer price for total tendered quantity, otherwise the bid should be treated as disqualified.

5.9 The whole supply may be split up between two or more bidders or accepted in part and not in entirety, if considered expedient.

5.10 The supplier(s) / bidder(s) ' is responsibility for this contract shall commence from the **15th day** of issue of **supply order** and the **delivery period shall be reckoned from the 15th day of issue of supply order automatically.**

5.11 Before submitting tenders, the tenderers are to satisfy themselves by actual visit to the site of work/supply as regards the prevailing conditions of approaches and roads and availability of laborers and materials etc. and tenderers submitting tender shall be deemed to have done so. No claim on the above will be entertained afterwards.

5.12 The tender for supply of materials shall remain open for acceptance for a period of 180 (One Eighty) days from the date of opening of tender. If any tenderer withdraws his tender before the said period or makes any modifications in the terms and conditions of the tender which are not acceptable to the TSECL, the TSECL shall without prejudice to any other right or remedy be at liberty to forfeit the said earnest money absolutely.

5.13 Power of Attorney, if given to authorized signatory for signing the Contract Agreement, shall be made in an INDIA NON-JUDICIAL STAMP OF Rs.100.00 (Rupees one hundred) only.

5.14 The bidding documents are not transferable and cost of bidding document is not refundable under any circumstances.

5.15 Promotional order in favour of Local SSI Unit of TRIPURA State :

To develop new manufacturer, promotional orders on new units of **TRIPURA State** having BIS (label-2) certificate for manufacturing of **63 KVA** Distribution Transformer will be placed for the quantity upto 10% of the total quantity for which Purchase Order would be issued against the tender. The original equipment manufacturers whose manufacturing unit is located in TRIPURA, who intend to participate in the tender to introduce their new units, may apply for promotional order by submitting Earnest Money (if not exempted).

“ APPLICATION FOR PROMOTIONAL ORDER” shall be written on the top in bold & capital letters in case of original equipment manufacturers intend to apply for promotional order as mentioned above.

If the bid of the new manufacturer is found techno-commercially eligible, their offer for promotional order will be processed separately after finalization of original tender subject to acceptance of the lowest evaluated rate of the tender by the vendor.

Financial proposal of the bidder for promotional order shall not be opened. Order may be placed at the discretion of TSECL, at the lowest evaluated rate of the Purchase Order against the original tender. However, placement of promotional order is not mandatory for each tender and shall be processed at the discretion of TSECL.

6.0 Contract performance guarantee

The successful bidder(s) shall furnish a **contract performance guarantee (CPG) @ 10 %** of the total contract value for a period of Guarantee period plus delivery period (CPG is to be extended further subject to actual delivery period) in the following manner :

- 50% of Contract Performance Guarantee (CPG) amount shall be deposited in the shape of bank guarantee (BG) from any nationalized bank, payable at Agartala as per TSECL's format favoring TSECL and
- the balance 50% will be deducted from running bills on pro-rata basis or
- minimum 10% of the balance amount whichever is higher from each bill till full realization of Contract Performance Guarantee (CPG) and this deduction should be completed before processing of final bill against every agreement.

EMD deposited during bid will be merged / adjusted with the eligible Contract Performance Guarantee (CPG) if required by the bidder.

N.B. Refer to Clause no 19.6, Section II.

6.1 Address for communication:

**Deputy General Manager (Materials Management)
Electrical Stores Division
Tripura State Electricity Corporation Limited
Arundhatinagar, Agartala. Tripura (West).
PIN: 799003 ; Ph: 0381 237 0282, Tele Fax: 0381 237 3099
E-mail :-dgmmaterial @ gmail.com**

DUPLICATE COPY TO BE SUBMITTED IN COVER NO.1
ACCEPTANCE LETTER AFTER DUE ATTESTION BY NOTARY
(TO BE SUBMITTED IN COVER NO.1)

Refer NIT No. _____ Date _____

To
The Deputy General Manager,
Material Management
Tripura State Electricity Corporation Limited
Stores Division
A.D.Nagar, Agartala, Tripura

Sir,

Acceptance of TSECL'S NIT Clause No. 4-(v) of Section –I

1. I/We hereby declare that I/We have gone through the NIT Clause No. 4-(x) of Section –I of this NIT.
2. I/We hereby declare the acceptance of the aforesaid mentioned clause.
3. I/We hereby on behalf of (the name of the Vendor/Firm.....) declare that we are not “De-barred/Black listed” by any Central (GOI)/State Govt owned Power Utility, for supply of similar materials during last 3 years for whatever reasons.

Date:.....

Yours faithfully,

(Signature of the Tenderer)
With rubber Stamp

Attestation Signature of Notary
With Rubber Stamp

Date:

SECTION-II

INSTRUCTION TO BIDDERS

1.0 GENERAL INSTRUCTIONS

The bidders are to satisfy themselves by actual site visit to the site of materials (F.O.R.) as regards the prevailing condition of approaches, transportation facilities availability of labourers and availability of materials etc. before submission of bid. No claim on this account will be entertained at any stage.

The location of the Electrical Stores Division under Deputy General Manager (Materials Management) is situated at Agartala, Arundhutinagar Tripura (West), at a distance of about 7 K.M. from AGARTALA, the nearest railway station in Tripura. The materials may be transported by road transport through the National Highway – 44.

2.0 COST OF BIDDING

The Bidder shall bear all the costs and expenses associated with preparation and submission of its Bid including post-bid discussions, technical and other presentation etc. and the TSECL shall in no case be responsible or liable for those costs, regardless of the conduct or outcome of the bidding process.

3.0 THE BIDDING DOCUMENT

3.1. CONTENTS OF BIDDING DOCUMENTS

The goods and services required, bidding procedures and contract terms are as prescribed in the Bidding Documents.

In addition to the Invitation for Bids, the Bidding Document is a compilation of the following sections:

- A] Section - I Notice Inviting Tender ;
- B] Section - II Instructions to the Bidders ;
- C] Section - III General Terms & Conditions of Contract ;
- D] Section - IV Technical Specification ;
- E] Section - V Price bidding schedule ;

3.2 UNDERSTANDING OF BIDDING DOCUMENTS

A prospective Bidder is expected to examine all instructions, forms, terms and specifications in the Bidding Documents and fully inform himself as to all the conditions and matters which may in any way affect the scope of work or the cost thereof. Failure to furnish all information required by the Bidding Documents or submission of a Bid not substantially responsive to the Bidding Documents in every respect shall be at the Bidder's risk and may result in the rejection of its Bid.

4.0 CLARIFICATIONS ON BIDDING DOCUMENTS

- 4.1. A prospective Bidder finds discrepancies or omissions in the specifications and documents or is in doubt as to the true meaning of any part or requires any clarification on Bidding Documents should make the request / notify the tender inviting authority of TSECL in writing. The concerned authority of TSECL shall respond in writing to any request for such clarification of the Bidding Documents, which it receives not later than fifteen (15) days prior to the deadline for submission of bids stipulated in tender notice. Written copies of the response (including an explanation of the query but without identifying its source) shall be sent to all prospective bidders who purchased the tender document.
- 4.2. Verbal clarification and information given by the Owner or his employee(s) or his representative (s) shall not in any way be binding on the Owner.

5.0 AMENDMENT TO BIDDING DOCUMENTS

- 5.1. At any time prior to the deadline for submission of bids, TSECL may, for any reason, whether at its own initiative or in response to a clarification requested by a prospective Bidder, modify the Bidding Documents by amendment(s).
- 5.2. The amendment shall be notified in writing or by electronic media to all prospective Bidders, who have received the Bidding Documents at the address contained in the letter of request for issue of Bidding Documents from the Bidders. TSECL shall bear no responsibility or liability arising out of non-receipt of the same in time or otherwise.
- 5.3. In order to afford prospective bidders reasonable time to take the amendment into account in preparing their bids, TSECL may, at its discretion, extend the deadline for submission of bids.
- 5.4. Such amendments, clarifications, etc shall be binding on the bidders and shall be given due consideration by the bidders while they submit their bids and invariably enclose such documents as a part of the Bid.

6.0 PREPARATION OF BIDS

6.1 LANGUAGE OF BID

The Bid prepared by the Bidders and all correspondence and documents relating thereto, exchanged by the Bidder and TSECL, shall be written in English language, provided that any printed literature furnished by the bidder may be written in another language so long as accompanied by an English translation of its pertinent passages. Failure to comply with this may disqualify a bid.

7.0 LOCAL CONDITIONS

- 7.1. It shall be imperative on each bidder to fully inform him of all local conditions and factors, which may have any effects on the execution of the contract covered under these documents and specifications. The Owner shall not entertain any request for clarification from bidders, regarding such local conditions.
- 7.2. It must be understood and agreed that such factors have properly been investigated and considered while submitting the proposals. No claim for financial adjustment to the Contract awarded under these specifications and documents shall be entertained by TSECL. Neither any change in the time schedule of the Contract nor any financial adjustments arising thereof shall be permitted by TSECL.

8.0 DOCUMENTS COMPRISING THE BID

The Bid shall be submitted in 2 (two) parts in separate sealed envelopes properly superscribing tender no, name of work and bid opening date as follows:

1st Part: PRE-QUALIFICATION & TECHNO-COMMERCIAL BID.

- i. Containing Bid earnest money as per the stipulations of the Bid Documents.
- ii. Containing Documentary evidence in fulfilling the requirements as indicated at **Sl.No.4.0 of Section-I** of the tender document. The Bidder shall also submit all such other documents deemed necessary in support of the stipulated qualifying requirement and its credentials.
- iii. Details of Bidder(s)/Tenderer (s) experience as per requirement to tender enquiry Format III (Section-IV).
- iv. The technical bid shall be consisting of all technical details, data sheet, and detail technical specification for the item offered. The technical bid will be opened first for detail verification and freezing of technical requirements as per NIT.

No commercial aspect will be entertained in Pre-qualification bid & Techno- commercial bid.

PRE-QUALIFICATION BID & TECHO-COMMERCIAL BID will be opened on same date .
The materials offered shall be fully type tested by the Bidder as per IS. The Type Test certificates shall be from **CPRI-Bangalore** or **ERDA, Vdodara**.

The essential requirement of the techno commercial bid is submission of “Type Test” certificate of the tendered item. The date of type tests report submitted, shall be not older than 5 (five) years as on the date of opening of the tender.

The Bids received without type test reports will be treated as Non-responsive and shall be rejected.

The GTP of technical bid should be supported by the type test report with respect to Impulse withstand voltage, losses, % impedance and limiting values of temperature rise. The technical bid shall be consisting of all technical details, data sheet, and detail technical specification for the item offered. The technical bid will be opened first for detail verification and freezing of technical requirements as per NIT..

Format-II (details of testing facilities) under section-IV must be duly filled in and submitted with this bid failing which PRICE BID will not be opened.

2nd Part: PRICE BID

Only the successful bidders qualified in **Pre qualification & Techno -commercial part** shall be considered for opening of Price bid. The Price bid shall be opened with prior intimation to the successful qualified bidders only.

9.0 SCOPE OF THE PROPOSAL

9.1. SCOPE OF THE PRE-QUALIFICATION & TECHNO-COMMERCIAL BID.

The scope of the proposal shall cover all/ the item(s) specified under the accompanying Technical Specification. It shall include the following:

- a. Detailed design of the item(s) as applicable.
- b. Guaranteed technical particulars to be furnished as per Format appended along with the technical bid.
- c. Information to be furnished by the tenderer/bidder for appraisal of firm's capability & capacity to manufacture tender item as per requirement to tender enquiry Format-I(Section-IV).
- d. Detail of Testing Facilities at manufacturer works as per requirement to tender enquiry Format-II (Section-IV).

9.2. SCOPE OF THE PRICE BID.

Bids containing deviations from provisions relating to the following clauses shall be considered as non-responsive:

- a) Price :-Clause 10,11,12.0,13.0 & 14.0 (Section-II)
- b) Contract Performance Guarantee:- Clause 6.0, Section-I
- c) Liquidated Damages:-Clause 13.0, General Condition of Contract (Section- III-GCC)
- d) Guarantee:- Clause 14.0, General Condition of Contract (Section- III-GCC)
- e) Payment:- Clause 27.0, General Condition of Contract (Section- III-GCC)

The determination of a Bid's responsiveness will be based on the contents of the Bid itself without recourse to extrinsic evidence.

- 9.3. Bids not covering the above entire Scope of Work shall be treated as incomplete and hence rejected.

10.0 BID PRICE

- 10.1 The Bidder shall quote unit rates in the appropriate schedule at SECTION-V of the Bid Form furnishing the price breakup as follows :

- i. Ex-works price of the equipment / materials (including tools and tackles etc.)
- ii. G.S.T. or any other levies legally payable on the transactions between the Owner and the Bidder.
- iii. Charges for transportation and insurance i/e loading, unloading storages at site (FOR) for delivery of the equipments / materials up to their final destinations.
- iv. Cost of Pre-despatch Inspection is to be optional and separately quoted so that TSECL can waive, if felt required.

A. The Price bidding schedule in Section-V shall be followed strictly, failing which or, account of any deviation taken by the bidders, their offers shall not be considered and rejected outright.

B. Inspection amount for lot-wise Inspection lot per person shall be quoted extra which shall include to-and-fro air fare including his Lodging and Boarding charges with local transportation cost. Pre-despatch Inspection cost per person shall be loaded during evaluation and it will be an OPTIONAL ITEM RATE to be charged when inspection is conducted as described by the TSECL. In event of waiving, no cost shall be borne by the suppliers.

11.0 PRICE BASIS

- 11.1 The bidders shall quote in their proposal price for the entire Scope of Supply covered under the Technical Specification as required in the Bid Proposal Sheets on price basis followed by Clause 14.0 of instruction to bidders.(SECTION-II)
- 11.2. Bidder shall indicate Bid prices in Indian Rupees only.

12.0 TAXES AND DUTIES

- 12.1. All applicable taxes, transportation, freight and insurance and other levies payable by the bidders in respect of the procurement of tendered item between the bidder and their vendors/sub-suppliers while procuring any components, sub-assemblies, raw materials and equipment shall be included in the bid price and no separate claim on this behalf shall be entertained by TSECL .
- 12.2. Any statutory increase in GST, beyond prevailing rate at the time of bidding shall be payable on production of documentary evidence during contractual delivery period. Benefit of statutory decrease in the rate of GST below the prevailing rate during bidding shall be passed on to TSECL.

13.0 Income Tax on goods incorporated in the Supply:

- 13.1. As regards the Income Tax surcharge on Income Tax and other corporate taxes, the Bidder shall be responsible for such payment to the concerned authorities.

14.0 HOW TO QUOTE PRICE.

- 14.1 Tenderer(s) / Bidder(s) shall quote **Firm rates** based on raw materials and the rate shall prevail throughout the contract execution period with no escalation whatsoever.
- 14.2 Ex-works rate & F.O.T. Electrical Storeyard A.D.Nagar Agartala, rate by Road Transport from place of despatch upto destination (Electrical Store's Subdivision, A.D.Nagar Agartala) should be furnished by the tenderer. Rate quoted will be presumed to indicate despatch by Road Transport.
- 14.3 Tender(s)/Bid(s) without indicating of aforesaid component shall be liable for rejection.
- 14.4 Any stores supplied if found not conforming to proper specification / damaged / broken may be rejected and the same will have to be taken back by the supplier concerned at their own cost within 15 days, time from the date of receipt of intimation from the DGM(MM), Electrical Stores Division, Arundhatinagar, Agartala/ Consignee. **If not taken back, the storage charges @ 2% per month of the cost of the returnable material shall be applicable.**
- 14.5 The bidder will be responsible for safe arrival of the materials in good condition for which the supplier will not be paid separately for transit insurance. Settlement of case with insurance will be the sole responsibility of the supplier. All breakages damages / shortages will be at the account of the supplier and shall be replaced by them.
- 14.6 Unloading of the materials at Electrical Storeyard will be the responsibility of supplier or his authorized carrier representative and the materials to be formally handed over to the concerned Manager / Sr.Manager in-charge of Electrical Store's Sub-division, A.D.Nagar, otherwise ex-partie decision on acceptability of materials will be taken by the Sr. Manager (Materials Management) in-charge of Electrical Store's Sub-division, A.D.Nagar, TSECL.

- 14.7 The bid offer should remain valid for 180 (one eighty) days from the dated of opening of the pre-qualification bid.
- 14.8 The bidder should be agreeable to supply **upto (+) 25 to (-)25%** of the Agreemented quantity and in same terms & condition, **if order for additional quantity is placed within Agreement period.**
- 14.9 The bidder should comply in toto with the delivery schedule of materials and maintain the quality of ordered materials, otherwise performance in future shall be affected badly.
- 14.10 Tenderer should be careful in quoting rates. Any rate, if in the analysis of the Corporation appears to be un-workable the tenderer will have to furnish full details of the costing with cost of materials, labour charges, supervision, handling and transport etc., whenever called for otherwise, such unreasonable rates offered are liable for rejection.
- 14.11 All intimation to bidder will be sent by e-mail / Fax / Post / telegraph / ordinary letter / Registered post for which clear addressed has to be given by the tenderer. A letter issued to the tenderer / Supplier in any of the above form will be presumed that he has been informed of the matter and the Corporation will not be liable for postal delay/lapse.
- 14.12 In case the bidder fails to execute the order within the schedule of delivery for reason attributable to him and if the Department / TSECL agrees to the extension of the delivery date, price rise if applicable within such extended period will not be entertained by the purchaser.
- 14.13 The Tender documents should invariably be submitted duly filled in all pages with signature of the tenderer.
- 14.14 Tender(s) with documents, if offered, in violation of N.I.T. conditions will be liable for rejection.
- 14.15 Bidder(s) should strictly comply with the check list attached with the tender documents just next to the Front Page.
- 14.16 The downloaded NIT should be submitted with Price bid.

15.0 TIME SCHEDULE/ DELIVERY SCHEDULE

- 15.1. The basic consideration and the essence of the Contract shall be strict adherence to the time schedule for performing the specified supply / works.
- 15.2. The requirement of completion schedule for the supply / works is mentioned in the accompanying Conditions of Contract.
- 15.3. The completion schedule as stated in the Conditions of Contract shall be one of the major factors in consideration of the Bids.
- 15.4 TSECL reserves the right to request for a change in the supply / work schedule during post-bid discussion with successful bidder.

15.5 The delivery shall be completed **within 6 (six) months** and shall be reckoned from 15th Day of the date of issue of the supply order and supply shall be started as –

- **60 nos within the 3rd month,**
- **30 nos within the 5th month and**
- **balance 30 nos within 6th month.**

In each lot the vendor should fulfill the stipulated quantity. They may supply more quantity even full quantity within each phase of supply but they should not supply less quantity in each phase. Levy will be imposed as per clause no 13.0 of Section-III, if delivery schedule is violated.

16.0 CONTRACT QUALITY ASSURANCE

- 16.1 The Bidder shall include in his proposal, the quality assurance programme containing the overall quality management and procedures which he proposed to follow in the performance of the supply/ works during various phases, as detailed in relevant clause of the General Technical Conditions.
- 16.2 At the time of award of Contract, the detailed quality assurance programme to be followed for the execution of the contract shall be mutually discussed and agreed to and such agreed programme shall form part of the contract.

17.0 INSURANCE

The bidder's insurance liabilities pertaining to the Scope of supply / work is detailed out in clauses titled insurance in General Terms & Conditions of Contract. Bidder's attention is specifically invited to these clauses. The bid price shall include all the cost in pursuance of fulfilling all the insurance liabilities under the Contract. The bidders shall replace the defective materials as desired by TSECL and all insurance matters are to be settled by the bidders at his own cost.

18.0 BRAND NAMES

- 18.1 The specific reference in these specifications and documents to any material/ equipment by brand name, make or catalogue number shall be construed as establishing standards of quality and performance and not as limiting competition. However, Bidders may offer other similar material/equipment provided they meet the specified standard, design and performance requirements. The Bidder shall furnish adequate technical information about such alternative material/equipment to enable TSECL to determine its acceptability. TSECL shall be the sole judge on the acceptability of such alternative material /equipment.
- 18.2 The Bidder shall note that standards for workmanship, material and equipment and reference to brand name or catalogue numbers designated by the Owner in its Technical Specification are intended to be descriptive only and not restrictive. The Bidder may substitute alternative standards, brand name and/or catalogue numbers in its Bid, provided that it demonstrates to the Owner's satisfaction that the substitutions are substantially equivalent or superior to those designed in the Technical Specification.

19.0 BID GUARANTEE

- 19.1 The Bidder shall furnish, as part of its Bid, earnest money for an amount as specified in the Notice Inviting Tender (NIT) in the shape of demand draft in favour of Deputy General Manager (MM), Electrical Stores Division, A.D.Nagar, Agartala, Tripura State Electricity Corporation Limited on any Schedule Bank, payable at Agartala, West Tripura.
- 19.2 The earnest money is required to protect TSECL against the risk of Bidder's conduct, which would warrant the earnest money forfeiture pursuant to Para 19.7.
- 19.3 The earnest money shall be deposited in Indian rupees only.
- 19.4 Any bid not secured in accordance with Para 19.1 and 19.3 above shall be rejected by TSECL as non-responsive.
- 19.5 The earnest money of the unsuccessful Bidders shall be discharged /returned as promptly as possible as but not later than 90 days after the expiration of the period of bid validity prescribed by the Owner.

- 19.6 The earnest money of the successful Bidder will be adjusted with the performance guarantee required to be furnished on award of contract as per clause 6.0 of Section – I.
- 19.7 The earnest money may be forfeited:
- a. If a Bidder withdraws its bid during the period of bid validity specified by the Bidder on the bid form; or
 - b. In case of a successful Bidder fails:
 - i. to sign the contract; or
 - ii. to furnish the performance guarantee.
- 19.8 No interest shall be payable by TSECL on the above earnest money.

20.0 PERIOD OF VALIDITY OF BIDS

- 20.1 **Bids shall remain valid for 6 (six) calendar months after the date of bid opening prescribed by TSECL**, unless otherwise specified in the accompanying Special Conditions of Contract. A Bid valid for a shorter period shall be rejected by TSECL as non-responsive.
- 20.2 In exceptional circumstances, TSECL may solicit the Bidder's consent to an extension of the period of Bid validity. The request and the response thereto shall be made in writing (including cable or fax). The Earnest money provided under clause 6.0 of Section – I shall also be retained upto the extended period. No interest shall be payable by TSECL for retaining the earnest money upto the extended period.

SUBMISSION OF BIDS

21.0 FORMAT OF BID

- 21.1 The Bid shall be submitted in two parts as described in clause no. 5.1 of Section – I.
- 21.2 The Bid shall contain no interlineations, erasures or overwriting except as necessary to correct errors made by the Bidder, in which case such corrections shall be initialed by the person or persons signing the Bid.

22.0 SIGNATURE OF BIDS

- 22.1 The Bid must contain the name, residence and place of business of the person or persons making the Bid and shall be signed and sealed by the Bidder with his usual signature. The names of all persons signing shall also be typed or printed below the signature.
- 22.2 Bid by a partnership must be furnished with full names of all partners and be signed with the partnership name, followed by the signature(s) and designation(s) of the authorized partner(s) or other authorized representative(s).
- 22.3 Bids by Corporation / Company must be signed with the legal name of the Corporation/Company by the President, Managing Director or by the Secretary or other person or persons authorized to Bid on behalf of such Corporation / Company in the matter.
- 22.4 A Bid by a person who affixes to his signature the word 'President', 'Managing Director', 'Secretary', 'Agent', or other designation without disclosing his principal shall be rejected.

- 22.5 Satisfactory evidence of authority of the person signing on behalf of the Bidder shall be furnished with the Bid.
- 22.6 The Bidder's name stated on the proposal shall be exact legal name of the firm.
- 22.7 Bids not conforming to all the above requirements of clause 22 above may be disqualified.
- 22.8 The original tender document shall be signed by the bidder on all pages and will be enclosed with the Price bid.
- 22.9 The Bidder shall have to give a DECLARATION that he /they have gone through the details of the bidding document as per format appended herewith.

23.0 SEALING AND MARKING OF BIDS

- 23.1 The two-part bid document shall be submitted followed by the Clause No. 5.1 of Section-I and the envelopes shall be addressed as follow.

**Deputy General Manager (Materials Management)
Electrical Stores Division
Tripura State Electricity Corporation Limited
Arundhatinagar, Agartala, Tripura (West).
Pin: 799003
Ph: 0381 237 0282, Tele Fax: 0381 237 3099
E-mail: dgmmaterial@gmail.com**

- 23.2 The earnest money and downloaded tender cost must be submitted in a separate sealed envelope with Pre-qualification & Techno-commercial bid.**

24.0 DEADLINE FOR SUBMISSION OF BIDS

- 24.1 The Bidders have the option of sending the Bid by registered post or submitting the Bid in person. Bids submitted by telex/telegram/fax shall not be accepted. No request from any Bidder to TSECL to collect the Bid from airlines, cargo agents etc. shall be entertained.
- 24.2 Bids shall be received by TSECL at the address specified under Clause 23.1 of section - II, not later than the time & date mentioned in the Invitation to Bid.
- 24.3 TSECL may, at its discretion, extend this deadline for the submission of Bids, in which case all rights and obligations of TSECL and Bidders previously subject to the deadline shall thereafter be subject to the deadline as extended.

25. LATE BIDS

- 25.1 Any Bid received by TSECL after the time & date fixed or extended for submission of Bids prescribed by TSECL, shall be rejected and/or returned unopened to the Bidder.

26. MODIFICATION AND WITHDRAWAL OF BIDS

- 26.1 The Bidder may modify or withdraw its Bid after the Bid's submission provided that written notice of the modification or withdrawal is received by TSECL prior to the deadline prescribed for submission of Bids.

- 26.2 The Bidder's modification or withdrawal notice shall be prepared, sealed, marked and dispatched in accordance with the provisions of clause 23 of section – II.
- 26.3 No Bid shall be modified / withdrawn in the interval between the deadline for submission of Bids and the expiration of the period of Bid validity specified by the Bidder on the Bid Form. Withdrawal/modification of a Bid during this interval shall result forfeiture of the earnest money deposited by the bidder.

27.0 INFORMATION REQUIRED WITH THE PROPOSAL

- 27.1 The Bids must clearly indicate the name of the manufacturer, the type of model of each principal item of equipment proposed to be furnished and erected. The Bid shall also contain drawings and descriptive materials indicating general dimensions, principles of operation, the extent of pre-assembly involved, major construction equipment proposed to be deployed, method of erection and the proposed erection organizational structure.
- 27.2 The above information shall be provided by the Bidder in the form of separate sheets, drawings, catalogues, etc. in five copies
- 27.3 Any bid not containing sufficient descriptive material to describe accurately the equipment proposed, shall be treated as incomplete and hence rejected. Such descriptive materials and drawings submitted by the Bidder shall be retained by TSECL. Any major departure from these drawings and descriptive material submitted shall not be permitted during the execution of the Contract without specific written permission of TSECL.
- 27.4 Oral statements made by the Bidder at any time regarding quality, quantity or arrangement of the equipment or any other matter shall not be considered.
- 27.5 Standard catalogue pages and other documents of the Bidder may be used in the Bid to provide additional information and data as deemed necessary by the Bidder.
- 27.6 In case of the proposal information contradicts specification requirements; the specification requirements shall govern, unless otherwise brought out clearly in the technical / commercial deviation schedule.

BID OPENING AND EVALUATION

28.0 OPENING OF BIDS BY TSECL

- 28.1 First the cover containing Earnest money and required documents of qualifying requirement as per clause 4.0 of Section-I shall be opened and only those Bidders whose Bid contains Earnest money and documents of qualifying requirements as per the stipulations of Section - I shall be considered eligible for opening of Part-II (Price Bid) of the Bid which will be opened on a date as intimated to the eligible bidders.

In case the above schedule date of opening of Bid is declared holiday by the State / Central Govt. the Bid will be opened on the following working day keeping time unaltered.

- 28.2 The Bid and its all parts shall be opened in the presence of Bidders' representatives (up to 2 persons) who choose to attend at the date and time for opening of bids indicated in the NIT or in case any

extension has been given thereto, on the extended bid opening date and time notified to all the Bidders, who have purchased the Bidding Documents. The Bidders' representatives who are present shall sign a register evidencing their attendance. No person / agent shall be allowed to present during of Bid without valid authorization from the concerned bidder.

28.3 The Bidders names, bid prices, modifications, bid withdrawals and the presence or absence of the requisite earnest money and such other details as TSECL, at its discretion, may consider appropriate shall be announced at the opening.

28.4 No electronic recording devices including photographs taken by mobile shall be permitted during bid opening.

29.0 CLARIFICATION OF BIDS

29.1 To assist in the examination, evaluation and comparison of Bids, TSECL may, at its discretion, ask the Bidder for a clarification of its Bid. The request for clarification and the response shall be in writing and no change in the price or substance of the Bid shall be sought, offered or permitted.

30.0 PRELIMINARY EXAMINATION

30.1 TSECL shall examine the Bids to determine whether they are complete, whether any computational errors have been made, whether required sureties have been furnished, whether the documents have been properly signed and whether the Bids are generally in order.

30.2 **Arithmetical errors shall be rectified on the following basis:**

In the case of item rate tenders, only rates quoted shall be considered. Any tender containing percentage below / above the rates quoted is liable to be rejected. Rates quoted by the contractor / supplier in item rate tender in figures & words shall be accurately filled in so that there is no discrepancy in the rates written in figures and words. However,

- i. If any discrepancy is noticed in quoting the amounts in figures and in words, then the quoted rates in words shall be considered for evaluation and placing of orders.
- ii. If the amount of an item is not worked out by the contractor or it does not correspond with the rate written either in figure or in words then the rates quoted by the contractor in words shall be taken as correct.
- iii. Where the rates quoted by the contractor in figures and in words tally, but the amount is not worked out correctly, the rates quoted by the contractor will unless otherwise proved be taken as correct and not the amount.
- iv. If the Bidder does not accept the correction of the errors as above, his bid shall be rejected and the amount of earnest money shall be forfeited.

The bidder shall ensure that the prices furnished by him are complete. In the case of not quoting of rates of any item (supply / erection) in the specified price schedules of the Bid Form, TSECL shall be entitled to consider the highest price of the tender for the purpose of evaluation and for the purpose of award of the contract, use the lowest prices of the tender.

30.3 Prior to the detailed evaluation, TSECL shall determine the substantial responsiveness of each Bid w.r.t. Bidding Documents. For purpose of these Clauses, a substantially responsive Bid is one which conforms to all the terms and conditions of the Bidding Documents without material deviations. A

material deviation is one which affects in any way the prices, quality, quantity or delivery period of the equipment or which limits in any way the responsibilities or liabilities of the Bidder or any right of TSECL as required in these specifications and documents. TSECL determination of a Bid's responsiveness shall be based on the contents of the Bid itself without recourse to extrinsic evidence.

- 30.4 A Bid determined as not substantially responsive shall be rejected by TSECL and may not subsequently be made responsive by the Bidder by correction of the non-conformity.
- 30.5 TSECL may waive any minor non-conformity or irregularity in a Bid which does not constitute a material deviation, provided such waiver does not prejudice or affect the relative ranking of any Bidder.

31.0 COMPARISON OF BIDS

- 31.1 Evaluated bid prices of all the bidders shall be compared among themselves to determine the lowest evaluated Bid and, as a result of this comparison, the lowest Bid may be selected for award of the Contract.

32.0 CONTACTING THE OWNER

Bids shall be deemed to be under consideration immediately after they are opened and until such time official intimation of award/rejection is made by TSECL to the Bidders. While the bids are under consideration, Bidders and/or their representatives or other interested parties are advised to refrain from contacting by any means, the Owner and/or his employees/representatives on matters relating to the bids under consideration. TSECL, if necessary, shall obtain clarifications on the bids by requesting for such information from any or all the Bidders, either in writing or through personal contacts as may be necessary. Bidders shall not be permitted to change the substance of the bids after the bids have been opened.

AWARD OF CONTRACT

33.0 AWARD CRITERIA

- 33.1 TSECL shall award the Contract to the successful Bidder whose bid has been determined to be substantially responsive and has been determined as the lowest evaluated Bid, provided further that the Bidder is determined to be qualified to perform the Contract satisfactorily. TSECL shall be the sole judge in this regard.
- 33.2 Further, **TSECL reserves the right to award separate Contracts to two or more parties in line with the terms and conditions specified in the accompanying Technical Specifications.**
- 33.3 **On being Awarded with LOA (Letter of Award), the successful bidder should confirm the unconditional acceptance of LOA duly signature with stamp.**

34.0 OWNER'S RIGHT TO ACCEPT ANY BID AND TO REJECT ANY OR ALL BIDS

- 34.1 TSECL reserves the right to accept or reject any bid, and to annul the bidding process and reject all bids at any time prior to award of contract, without thereby incurring any liability to the affected Bidder or Bidders or any obligation to inform the affected Bidder or Bidders of the grounds for such action.

35.0 NOTIFICATION OF AWARD

- 35.1 Prior to the expiration of the period of bid validity and extended validity period, if any, TSECL shall notify the successful Bidder in writing by registered letter or by cable or telex or FAX, to be confirmed in writing by registered letter, that his Bid has been accepted.
- 35.2 The Notification of Award / Letter of Award shall constitute the formation of the Contract.
- 35.3 Upon the successful Bidder's furnishing of Contract Performance Guarantee pursuant to Clause 6.0 of section – I. TSECL shall promptly notify each unsuccessful Bidder and will discharge its bid guarantee, on their request.

36.0 SIGNING OF CONTRACT

- 36.1 At the same time as TSECL notifies the successful Bidder that its bid has been accepted, TSECL shall send the Bidder the detailed Letter of Supply Order. The successful bidder shall provide a confirmation letter in writing to the DGM(MM), Electrical Stores Division, A.D.Nagar, Agartala, TSECL for an unconditional acceptance of the LOA.
- 36.2 Within **15 days** of receipt of the detailed Letter of Supply Order, the successful Bidder shall attend the respective office of TSECL **for signing the contract agreement.**

37.0 MEANING OF CONTRACT PERFORMANCE GUARANTEE

- 37.1 As a Contract Performance Security, the successful Bidder, to whom the work is awarded, shall be required to furnish a contract Performance Guarantee in the shape of demand draft on any Schedule Bank in favour of DGM(MM), Electrical Stores Division, A.D. Nagar, Agartala, Tripura State Electricity Corporation Limited payable at Agartala, West Tripura. The guarantee amount shall be equal to ten percent (10 %) of the Contract Price and it shall guarantee the faithful performance of the Contract in accordance with the terms and conditions specified in these documents and specifications. The earnest money deposited at the time of tender shall be adjusted with the contract performance guarantee. The performance guarantee amount shall be deposited in accordance with the Clause 6.0 of Section-I.
- 37.2 **The Performance Guarantee** shall cover additionally the following guarantees to TSECL:
- a. The successful Bidder guarantees the successful and satisfactory operation of the materials / equipment supplied under the Contract, as per the specifications and documents.
 - b. The successful Bidder further guarantees that the material(s) / equipment supplied by him shall be free from all defects in design, material and workmanship and shall upon written notice from TSECL fully remedy free of expenses to TSECL such defects as developed under the normal use of the said materials/equipment within the period of guarantee specified in the relevant clause of the General Terms and conditions / Special Conditions of Contract.
- 37.3 The Contract Performance Guarantee is intended to secure the performance of the entire contract.
- 37.4 The Contract performance Guarantee amount shall be returned to the Contractor **without any interest** at the end of successful completion of the supply against a Bank Guarantee of equivalent amount from any Nationalized Bank valid upto the guarantee period.

38.0 CORRUPT OR FRAUDULENT PRACTICES

- 38.1 TSECL expects the bidders / suppliers / contractors observe the highest of ethics during the procurement and execution of such contracts. In pursuance of this policy, TSECL .
- a. Defines, for the purpose of this provision, the terms set forth below as follows;
 - i) “Corrupt practice” means offering, giving, receiving or soliciting of anything of value to influence the action of a official in the procurement process or in contract execution, and
 - ii) “Fraudulent practice” means a misrepresentation of facts in order to influence a procurement process or the execution of a contract to the detriment of the owner, and includes collusive practice among bidders (prior to or after bid submission) designed to establish bid prices at artificial non-competitive levels and to deprive the owner from the benefits of free and open competition.
 - b. Will reject a proposal for award if it determines the bidder recommended for award has engaged a corrupt or fraudulent practice in competing for the contract in question.
 - c. Will declare a firm ineligible, either indefinitely or for a stated period of time, if owner any time determines that the firm has engaged corrupt / fraudulent practices in competing for, or in executing the contract.

XXXXXXXX

SECTION-III

GENERAL TERMS & CONDITIONS OF CONTRACT

A. INTRODUCTION

1.0 DEFINITION OF TERMS

- 1.1 ‘The Contract’ means the agreement entered into between Tripura State Electricity Corporation Limited and Contractor as per the Contract Agreement signed by the parties, including all attachments and appendices thereto and all documents incorporated by reference therein.
- 1.2 ‘Contractor’ or ‘Manufacturer’ shall mean the Bidder whose bid shall be accepted by TSECL for award of the Works and shall include such successful Bidder’s legal representatives, successors and permitted assigns.
- 1.3 ‘Sub-contractor’ shall mean the person named in the Contract for any part of the Works or any person to whom any part of the Contract has been sublet by the Contractor with the consent in writing of the Executive Engineer-in-charge of the work and shall include the legal representatives, successors and permitted assigns of such person.
- 1.4 ‘Consulting Engineer’/’Consultant’ shall mean any firm or person duly appointed as such from time to time by TSECL .
- 1.5 The terms ‘Equipment’, ‘Stores’ and ‘Materials’ shall mean and include equipment, stores and materials to be provided by the Contractor under the Contract.

- 1.6 'Works' shall mean and include the furnishing of equipment, labour and services, as per the Specifications and complete erection, testing and putting into satisfactory operation including all transportation, handling, unloading and storage at the Site as defined in the Contract.
- 1.7 'Specifications' shall mean the Specifications and Bidding Documents forming a part of the Contract and such other schedules and drawings as may be mutually agreed upon.
- 1.8 'Site' shall mean and include the land and other places on, into or through which the works and the related facilities are to be erected or installed and any adjacent land, paths, street or reservoir which may be allocated or used by TSECL or Contractor in the performance of the Contract.
- 1.9 The term 'Contract Price' shall mean the item wise price / lump-sum price quoted by the Contractor in his bid with additions and/or deletions as may be agreed and incorporated in the Letter of Award, for the entire scope of the works.
- 1.10 The term 'Erection Portion' of the Contract price shall mean the value of field activities of the works including erection, testing and putting into satisfactory operation including successful completion of performance and guarantee tests to be performed at Site by the Contractor including cost of insurances.
- 1.11 'Manufacturer's Works' or 'Contractor's Works', shall mean the place of work used by the manufacturer, the Contractor, their collaborators/associate or sub-contractors for the performance of the Contract.
- 1.12 'Inspector' shall mean TSECL or any person nominated by TSECL from time to time, to inspect the item(s) to be supplied / equipment; stores or Works under the Contract and/or the duly authorized representative of TSECL.
- 1.13 'Notification of Award of Contract'/Letter of Award'/Telex of Award' shall mean the official notice issued by TSECL notifying the Contractor that his bid has been accepted.
- 1.14 'Date of Contract' shall mean the date on which Notification of Award of Contract/Letter of Award/Telex of Award has been issued.
- 1.15 'Month' shall mean the calendar month. 'Day or 'Days', unless herein otherwise expressly defined, shall mean calendar day or days of 24 hours each.
A 'Week' shall mean continuous period of seven (7) days.
- 1.16 "Writing" shall include any manuscript, type written or printed statement, under or over signature and/or seal as the case may be.
- 1.17 When the words 'Approved'. Subject to Approval', 'Satisfactory', 'Equal to', 'Proper', 'Requested', 'As Directed', 'Where Directed', 'When Directed', 'Determined by', 'Accepted', 'Permitted', or words and phrases of like importance are used, the approval, judgment, direction etc. is understood to be a function of TSECL.
- 1.18 "Test on Completion" shall mean such tests as prescribed in the Contract to be performed by the Contractor/Supplier(s) before the work is Taken Over by TSECL.

- 1.19 'Start Up' shall mean the time period required to bring the material(s)/ equipment covered under the Contract from an inactive condition, when construction is essentially complete, to the state ready for trial operation. The startup period shall include preliminary inspection and checkout of equipment and supporting sub-system, initial operation of the complete supplied item/equipment covered under the Contract to obtain necessary pre-trial operation data, perform calibration and corrective action, shut down, inspection and adjustment prior to the trial operation period.
- 1.20 "Initial Operation" shall mean the first integral operation of the complete equipment covered under the Contract with the sub-system and supporting equipment in service or available for service.
- 1.21 'Trial Operation', 'Reliability Test', 'Trial Run', 'Completion Test' shall mean the extended period of time after the start up period. During this trial operation period, the unit shall be operated over the full load range. The length of Trial Operation shall be as determined by the Engineer of TSECL unless otherwise specified elsewhere in the Contract.
- 1.22 'Performance and Guarantee Test' shall mean all operational checks and tests required to determine and demonstrate capacity, efficiency and operating characteristics as specified in the Contract Documents.
- 1.23 The term 'Final Acceptance/Taking Over' shall mean acceptance of the Works performed under the Contract by TSECL, after successful completion of Performance and Guarantee Tests, as specified in the accompanying Technical Specification or otherwise agreed in the Contract.
- 1.24 "Commercial Operation" shall mean the Conditions of Operation in which the complete supply item(s)/ equipment covered under the Contract is officially declared by TSECL to be available for continuous operation at different loads upto and including rated capacity. Such declaration by TSECL, however, shall not relieve or prejudice the Contractor of any of his obligations under the Contract.
- 1.25 'Guarantee period'/'Maintenance Period' shall mean the period during which the Contractor shall remain liable for repair or replacement of any defective part(s) of the works/Supplies performed under the contract.
- 1.26 'Latent Defects' shall mean such defects caused by faulty designs, material or work man ship which cannot be detected during inspection, testing etc, based on the technology available for carrying out such tests.
- 1.27 'Drawings', 'Plans' shall mean all:
- a) Drawing furnished by TSECL as a basis for Bid Proposals.
 - b) Supplementary drawings furnished by TSECL to clarify and define in greater detail the intent of the Contract.
 - c) Drawings submitted by the Contractor with his Bid provided such drawings are acceptable to TSECL.
 - d) Drawings furnished by TSECL to the Contractor during the progress of the Supplies/Work; and
 - e) Engineering data and drawings submitted by the Contractor during the progress of the supplies / Work provided such drawings are acceptable to the Executive Engineer in charge of the work.

- 1.28 “Codes” shall mean the following including the latest amendments and / or replacement, if any:
- a) A.S.M.E. Test Codes.
 - b) A.I.E.E. Test Codes.
 - c) American Society of Testing Materials Codes.
 - d) Standards of the Indian Standards Institutions.
 - e) Other Internationally approved standards and / or Rules and Regulations touching the subject matter of the Contract.
- 1.29 Words imparting ‘Person’ shall include firms, companies, corporation and association or bodies of individuals.
- 1.30 Terms and expressions not herein defined shall have the same meaning as are assigned to them in the Indian Sale of Goods Act (1930), failing that in the Indian Contract Act (1872) and failing that in the General Clauses Act (1897) including amendments thereof if any.
- 1.31 In addition to the above the following definitions shall also apply.
- a) ‘All equipment and materials’ to be supplied shall also mean ‘Goods’.
 - b) ‘Contract Performance Guarantee shall also mean ‘Contract Performance Security’

2.0 APPLICATION

These General Conditions shall apply to the extent that they are not superseded by provisions in other parts of the Contract.

3.0 STANDARDS

The Goods supplied under this Contract shall conform to the standards mentioned in the Various Technical Specifications and when no applicable standard is mentioned; to the authoritative standard appropriate to the Goods and such standards shall be the latest issued by the concerned institution.

4.0 LANGUAGE AND MEASURES

All documents pertaining to the Contract including specification, Schedules, notices, correspondence, operating and maintenance instructions, drawings or any other writing shall be written in English language. The Metric System of measurement shall be used exclusively in the Contract.

5.0 CONTRACT DOCUMENTS

- 5.1 The term “Contract Documents” shall mean and include the following which shall be deemed to form an integral part of the Contract:
- a) Invitation of Bid including letter forwarding the Bidding Documents, Instructions to Bidders, General Terms and Conditions of Contract, Erection Conditions of Contract and all other documents included under the Special Conditions of Contract and various other sections.
 - b) Specifications of the item(s)/material(s) to be furnished under the Contract as brought out in the accompanying Technical Specification.
 - c) Bidders’ Bid proposal and the documents attached there-to including the letter of clarifications thereto between the Contractor and TSECL prior to the Award of Contract.

- d) All the materials, literature, data and information of any sort given by the Bidder along with his bid, subject to the approval of TSECL.
- e) Letter of Award and any agreed variations of the conditions of the documents and special terms and conditions of contract if any.

6.0 USE THE CONTRACT DOCUMENTS AND INFORMATION

6.1 The Bidder(s) shall not communicate or use in advertising, publicity, sales releases or in any other medium, photographs or other reproduction of the Works under this contract, or descriptions of the site, dimensions, quantity, quality, or other information, concerning the Works unless prior written permission has been obtained from TSECL.

7.0 MANNER OF EXECUTION OF CONTRACT

- 7.1 The bidder should attend the concerned office of TSECL within 15(fifteen) days from the date of issue of the Letter of Award to the Contractor for signing the contract agreement.
- 7.2 The Bidders shall provide for signing of the Contract, Performance Guarantee, appropriate power of attorney and other requisite materials.
- 7.3 The Agreement shall be signed in two originals and the bidders shall be provided with one signed original and the rest shall be retained by TSECL.
- 7.4 The bidders shall provide free of cost to TSECL all the engineering data, drawings, and descriptive materials submitted with the Bid, in at least six (6) copies to form a part of the contract immediately after issue of Letter of Award.
- 7.5 Subsequent to signing of the Contract, the Contractor, at his own cost, shall provide TSECL with at least ten (10) true copies of Agreement within thirty (30) days after the signing of the Contract.

8.0 ENFORCEMENT OF TERMS

8.1 The failure of either party to enforce at any time any of the provisions of this Contract or any rights in respect thereto or to exercise any option therein provided, shall in no way be construed to be a waiver of such provisions, rights or options or in anyway to affect the validity of the Contract. The exercise by either party of any of its rights herein shall not prejudice either party from exercising the same or any other right it may have under the Contract.

9.0 COMPLETION OF CONTRACT

9.1 Unless otherwise terminated under the provisions of any other relevant clause, this Contract shall be deemed to have been completed on the date stipulated in the NIT.

B. GUARANTEE & LIABILITIES

10.0 TIME – THE ESSENCE OF CONTRACT

10.1 The time and the date of completion of the Contract as stipulated in the Contract by TSECL without or with modifications, if any, and so incorporated in the Letter of Award, shall be deemed to be the

essence of the Contract. The Contractor shall so organize his resources and perform his Work as to complete it not later than the date agreed to.

- 10.2 The bidder(s) shall submit a detailed within the time frame agreed consisting of adequate number of activities covering various key phases of the Supply/Work such as design, procurement, manufacturing, shipment and field erection activities within fifteen (15) days of the date of Notice of Award of Contract. This Bar Chart shall also indicate the interface facilities to be provided by TSECL and the dates by which such facilities are needed. The Contractor shall discuss with TSECL for finalization and approval of the Bar Chart by TSECL. The agreed Bar Chart shall form part of the contract documents. During the performance of the Contract, if in the opinion of the Deputy General Manager (Materials Management) in charge of the work, proper progress is not maintained, suitable changes shall be made in the Contractor's operations to ensure proper progress without any cost implication to TSECL. The interface facilities to be provided by TSECL in accordance with the agreed Bar Chart shall also be reviewed while reviewing the progress of the Contractor. Refer to 'Delivery schedule' as in NIT Clause no 15.0 to 15.5 of Section-II.
- 10.3 Subsequent to the finalization of the Bar Chart, the Contractor shall make available to the in charge of the work, a detailed manufacturing programme in line with the agreed Contract Bar Chart. Such manufacturing programme shall be reviewed, updated and submitted to the DGM(MM) in charge of the work once in every month thereafter.
- 10.4 The manufacturing programme shall be compatible with TSECL computer environment and furnished to TSECL on such media as may be desired by TSECL.

11.0 EFFECTIVENESS OF CONTRACT

- 11.1 The Contract shall be considered as having come into force from the date of the Notification of Award, unless otherwise provided in the Notification of Award.

12.0 EXTENSION OF TIME

- 12.1 The TSECL may consider to grant extension of time for the completion of the supply if it is felt absolutely essential on fulfillment of following conditions by the bidder:-
- a) The successful bidder must apply to the Engineer-in-charge in writing for extension of time in writing so required justifying the necessity.
 - b) Such application must state the grounds which hindered the bidders in the execution of the work within the time as stipulated in the contract document / agreement.
 - c) Such application must be made within 30 days of the date on which such hindrance had arisen.
 - d) The Engineer-in-charge must be of the opinion that the grounds shown for the extension of time are reasonable and without extension of such time completion of the work is practically impossible.
- 12.2 According to the terms of the contract the Engineer- in -charge has full powers, but the orders on the application of the bidders connected with the agreement accepted by the authorities higher than the Engineer- in -charge should be issued by him only after written approval of the authorities higher than the Engineer-in-charge.

12.3 The opinion of the Engineer-in-charge, whether the grounds shown for the extension of time are or are not reasonable, is final. If the Engineer-in-charge is of the opinion that the Grounds shown by the bidders are not reasonable and declines to grant extension of time, the bidders cannot challenge.

13.0 LIQUIDATED DAMAGES

13.1 **In case the materials are not delivered within the time stipulated in the Delivery schedule as per NIT Clause no 15.5 Section - II, the successful bidder shall be liable to pay at the discretion of the competent authority of purchaser, the liquidated damages to be determined by the purchaser as 1% of the delivered price of the delayed goods or un-performed services for each week of delay until actual delivery or performance subject to a maximum deduction of 10% of the delayed goods / services price. Due consideration may be given in the levy of damages for reasons absolutely beyond the control of the supplier for which documentary evidence shall be provided to the satisfaction of the competent delayed supplies.**

Delay shall be accepted with levy upto 60 actual days. After 60 days, the contract may or may not be continued with TSECL discretion.

14.0 GUARANTEE

14.1 The materials which are to be supplied, shall be guaranteed for a period of 36 months from the date of receipt at the stores of the Utility or 24 months from the date of commissioning, whichever is earlier.

14.2 The materials found defective within the above guarantee period shall be repaired / replaced by the supplier free of cost within three months of receipt of intimation. If the defective materials are not repaired/ replaced within the specified period, the purchaser shall recover an equivalent amount plus 15 % supervision charges from any of his bills or from the performance guarantee deposit.

15.0 TAXES, PERMITS & LICENCES

The Contractor/Supplier(s) shall be liable and pay all non-Indian taxes, duties, levies lawfully assessed against TSECL or the Contractor in pursuance of the Contract. In addition, the Contractor shall be responsible for payment of all Indian duties, levies and taxes lawfully assessed against this contract.

16.0 ARBITRATION

16.1 All disputes or differences in respect of which the decision, if any, of the Engineer has not become final or binding as aforesaid shall be settled by arbitration in the manner hereinafter provided.

16.2 The arbitration shall be conducted by three arbitrators, one each to be nominated by the Contractor and the Owner and the third to be appointed as an umpire by both the arbitrators in accordance with the Indian Arbitration Act. If either of the parties fails to appoint its arbitrator within sixty (60) days after receipt of a notice from the other party invoking the Arbitration clause, the arbitrator appointed by the party invoking the arbitration clause shall become the sole arbitrator to conduct the arbitration.

16.3 The arbitration shall be conducted in accordance with the provisions of the Indian Arbitration & Reconciliation Act, 1996 or any statutory modification thereof. The place & venue of arbitration shall be AGARTALA.

16.4 The decision of the majority of the arbitrators shall be final and binding upon the parties. The arbitrators may, from time to time with the consent of all the parties enlarge the time for making the award. In the event of any of the aforesaid arbitrators dying, neglecting, resigning or being unable to

act for any reason, it will be lawful for the party concerned to nominate another arbitrator in place of the outgoing arbitrator.

- 16.5 The arbitrator shall have full powers to review and/or revise any, decision, opinion, direction, certification or valuation of the Engineer in accordance with the Contract, and neither party shall be limited in the proceedings before such arbitrators to the condense or arguments out before the Engineer for the purpose of obtaining the said decision.
- 16.6 No decision given by the Engineer in accordance with the foregoing provisions shall disqualify him as being called as a witness or giving evidence before the arbitrators on any matter whatsoever relevant to the dispute or difference referred to the arbitrators as aforesaid.
- 16.7 During settlement of disputes and arbitration proceedings, both parties shall be obliged to carry out their respective obligations under the Contract.

17.0 LEGAL JURISDICTION

- 17.1 Any dispute or difference arising under/out of or in connection with this tender or contract shall be subject to exclusive jurisdiction of the local High Court.

18.0 DEDUCTION

- 18.1 Any amount which becomes payable by the supplier under particular contract shall be deducted by the purchaser from any amount that is due or becoming due under the same or any other contract and shall be adjusted.

19.0 LIMITATION OF LIABILITIES

- 19.1 The final payment by TSECL in pursuance of the Contract shall mean the release of the Contractor from all his liabilities under the Contract. Such final payment shall be made only at the end of the Guarantee/Warranty Period, and till such time as the contractual liabilities and responsibilities of the Contractor, shall prevail. All other payments made under the Contract shall be treated as on-account payments.

20.0 PRE-DISPATCH INSPECTION

- 20.1 The manufacturer shall offer Pre-despatch Inspection call at least 15(fifteen) days prior to the date of inspection to be held.
- 20.2 Dispatch of material is subjected to pre-dispatch inspection/testing by the purchaser's representative/engineers and clearance thereof. All acceptance tests and inspection shall be carried out as guided by the relevant I.S. at the place of manufacture unless otherwise specially agreed upon by the purchaser and the supplier at the time of purchase.

In case of waiver of inspection, the consignee will be at liberty for testing of material in the laboratories of Tripura or outside for acceptance if required, at the cost of the supplier.

- 20.3 The manufacturer shall offer to the inspectors representing the purchaser all the reasonable testing facilities free of charge for inspection and testing to satisfy that material being supplied is in accordance with the specifications.
- 20.4 The purchaser's representative/engineer attending above testing will carry out testing of suitable number of items as per the sampling procedure laid down in the corresponding IS as the case may be and issue test certificate approval to the manufacturer and give clearance for dispatch.

However, the final clearance will be given by the consignee after necessary verifications and tests at destination.

- 20.5 All expenses involved due to lodging & boarding to stay outside the State (TRIPURA) for conducting pre-dispatch acceptance test including fare for To & Fro journeys, shall have to be borne by the supplier. Re-imbursement will be made as per rate quoted by the bidder.
- 20.6 Mode of Transport from Agartala, (Tripura) to destination place of manufactures works, shall be by Air. In case where Air transport is un-available, for journeys on-wards Kolkata , Rail transport of A.C. Two Tiers shall be arranged.
- 20.7 Number of inspecting engineer(s) may vary to a maximum strength of 2(two) and shall be determined by the TSECL depending on quantity and methodology of testing.

21.0 INSPECTION AFTER RECEIPT OF STORES

- 21.1 The purchaser shall have option to test the samples selected at random from the supply affected to ensure that the supplies conform in quality and workmanship to the relevant specifications and also conform to the approved sample.
- 21.2 Fifteen days advance intimation will be given to the suppliers to depute representative to witness the tests. If they fail to be present, the testing will be carried out in absence of their representative on the schedule date. If the materials fail, in above random sample testing, the lot will be rejected.
- 21.3 No testing charges would be recovered for the first testing. In case the repaired/ replaced supplied item fail again on testing, the charges for testing together with all incidental expenses incurred by the purchaser shall be borne by the suppliers.
- 21.4 The materials supplied against the order and not conforming to the specifications shall have to be collected by the supplier at his cost, on refunding the amounts paid therefore, within 15 days of intimation of failure of materials on testing.

22.0 CHANGE OF QUANTITY

- 22.1 During the execution of the Contract, TSECL reserves the right to increase or decrease the quantities of items under the Contract but without any change in unit price or other terms & conditions. Such variations unless otherwise specified in the **accompanying Special Conditions of Contract and / or Technical Specification**, shall not be subjected to any limitation for the individual items but the total variations in all such items under the Contract shall be limited to a percentage of the Contract price as specified in the **Special Conditions of Contract**.
- 22.2 The Contract price shall accordingly be adjusted based on the unit rates available in the Contract for the change in quantities as above. The base unit rates, as identified in the Contract shall however remain constant during the currency of the Contract, except as provided for in clause 27.0 below. In case, the unit rates are not available for the change in quantity, the same shall be subjected to mutual agreement.

23.0 PAKCING, FORWARDING AND SHIPMENT

- 23.1 The Supplier/ Contractor shall pack and crate all equipment in such a manner as to protect them from deterioration and damage during rail and road transportation to the site and storage at the site till the time of erection. The Contractor shall be held responsible for all damages due to improper package.
- 23.2 The Supplier/Contractor shall notify the DGM (MM) in charge of the work of the date of each shipment from his works, and the expected date of arrival at the site.
- 23.3 The Supplier/Contractor shall also give all shipping information concerning the weight, size and content of each packing including any other information the DGM (MM) in charge of the work may require.
- 23.4 The Supplier/Contractor shall prepare detailed packing list of all packages and containers, bundles and loose materials forming each and every consignment dispatch to Site.

The Supplier/Contractor shall further be responsible for making all necessary arrangements for loading, unloading and other handling of the materials, right from his works up to the Site.

24.0 NO WAIVER RIGHTS OF AGREEMENT/CONTRACT PROVISION

- 24.1 Neither the inspection by TSECL nor any order by TSECL for payment of money or any payment for or acceptance of, the whole or any part of the supply by the DGM in charge of the supply, nor any possession taken by the DGM in charge of the supply shall operate as a waiver of any provision of the Contract, or of any power herein reserved to TSECL or any right to damages herein provided nor shall any waiver of any breach in the Contract be held to be a waiver of any other or subsequent breach.

25.0 CERTIFICATE NOT TO AFFECT RIGHT OF TSECL AND LIABILITY OF CONTRACTOR.

- 25.1 No interim payment certificate of the DGM(MM) in charge of the work, nor any sum paid on account by TSECL, nor any extension of time for execution of the Works granted by TSECL shall affect or prejudice the rights of TSECL against the Contractor or relieve the Contractor of his obligation for the due performance of the Contractor, or be interpreted as approval of the Works done or of the equipment furnished and no certificate shall create liability for TSECL to pay for alterations, amendments, variations or additional works not ordered, in writing , by the DGM(MM) in charge of the work or discharge the liability of the Contractor for the payment of damages whether due, ascertained or certified or not or any sum against the payment of which he is bound to indemnify TSECL, nor shall any such certificate nor the acceptance by him of any sum paid on account or otherwise affect or prejudice the rights of TSECL against the Contractor.

CONTRACT SECURITY AND PAYMENTS

26.0 CONTRACT PERFORMANCE GUARANTEE

- 26.1 The Supplier/Contractor shall furnish contract performance guarantee as specified in clause 6.0 of Section - I & Clause 37 of Section-II for the proper fulfillment of the Contract in the shape of demand draft in favour of Tripura State Electricity Corporation Limited payable at Agartala, West Tripura within fifteen (15) days of "Notice of Award of Contract."

27.0 PAYMENT

27.1 The payment to the Supplier/Contractor for the performance of the Supply/Works under the Contract will be made by TSECL as per the guidelines and conditions specified herein. All payment made during the Contract shall be on account payee cheque only. In the event of payment through demand draft, bank charge if any shall be at contractor account. The final payment will be made on completion of all Supply/Works and on completion of warranty / guaranty period including fulfillment by the Contractor of all his liabilities under the Contract.

27.2 Currency of Payment

All payments under the Contract shall be in Indian Rupees only.

28.0 Due Dates for Payments

TSECL will make progressive payment as and when the payment is due as per the terms of payment. No interest will be paid for delayed payment by TSECL if claimed by the supplier / contractor whatsoever.

29.0 Mode of Payment

29.1 Payment due on supply materials / services shall be made by the DGM in charge for execution of the agreement through account payee cheque.

30.0 Terms of Payment

- a). 100% Payment shall be made in accordance of the delivery schedule as stated, on receipt of the materials in good conditions at Store by the consignee subject to the deduction of balance CPG as well as levy if applicable and as guided in clause No. 27 to 30 of Section III of the NIT.
- b). For tenderer(s) / supplier(s) outside the State of Tripura cheque will be drawn on S.B.I or other Schedule Bank, payable at the place where the supply order is placed.
- c). For tenderer within the State of Tripura cheque will be drawn on S.B.I, T.L.A Branch or other Schedule Bank, Agartala.
- d). Any terms of advance payments i.e. payments against dispatch documents / Bank documents will not be acceptable.
- e). **In no circumstances, claim of interest on payment shall be entertained.**

31.0 INSURANCE

31.1 The Contractor at his cost shall arrange, secure and maintain all insurance as may be pertinent to the Works and obligatory in terms of law to protect his interest and interests of the Owner against all perils detailed herein. The form and the limit of such insurance as defined herein together with the under-writer in each case shall be acceptable to the Owner. However, irrespective of such acceptance, the responsibility to maintain adequate insurance coverage at all times during the period of Contract shall be of the Contractor alone. The Contractor's failure in this regard shall not relieve him of any of his contractual responsibilities and obligations. The insurance covers to be taken by the Contractor shall be in a joint name of the Owner and the Contractor. The Contractor shall,

however, be authorized to deal directly with Insurance Company or Companies and shall be responsible in regard to maintenance of all insurance covers. Further the insurance should be in freely convertible currency.

- 31.2 The transfer of title shall not in any way relieve the Contractor of the above responsibilities during the period of Contract. The Contractor shall provide the Owner with copy of all insurance policies and documents taken out by him in pursuance of the Contract. Such copies of documents shall be submitted to the Owner immediately after such insurance coverage. The Contractor shall also inform the Owner in writing at least sixty (60) Days in advance regarding the expiry/cancellation and/or change in any of such documents and ensure revalidation, renewal etc., as may be necessary well in time.
- 31.3 The perils required to be covered under the insurance shall include, but not be limited to fire and allied risks, miscellaneous accidents (erection risks) workman compensation risks, loss or damage in transit, theft, pilferage riot and strikes and malicious damages, civil commotion, weather conditions, accidents of all kinds, etc. The scope of such insurance shall be adequate to cover the replacement/reinstatement cost of the equipment for all risks upto and including delivery of goods and other costs till the equipment is delivered at Site. The insurance policies to be taken should be on replacement value basis and/or incorporating escalation clause. Notwithstanding the extent of insurance cover and the amount of claim available from the underwriters, the Contractor shall be liable to make good the full replacement/rectification value of all equipment/materials and to ensure their availability as per project requirements.
- 31.4 All costs on account of insurance liabilities covered under the Contract will be to Contractor's account and will be included in Contract Price, However, the Owner may from time to time, during the pendency of the Contract, ask the Contractor in writing to limit the insurance coverage, risks and in such a case, the parties to the Contract will agree for a mutual settlement, for reduction in Contract price to the extent of reduced premium amount. The Contractor, while arranging the insurance shall ensure to obtain all discounts on premium, which may be available for higher volume or for reason of financing arrangement of the project.
- 31.5 The clause entitled 'Insurance' under the Section ECC, covers the additional insurance requirements for the portion of the works to be performed at the Site.

32.0 LIABILITY FOR ACCIDENTS AND DAMAGES

- 32.1 Under the Contract, the Contractor shall be responsible for loss or damage to the equipment until the successful completion of commissioning as defined else-where in the Bidding Documents.
- 32.2 Any loss or damage to the goods during handling, transportation, stacking shall be to the account of the Contractor. The Contractor shall be responsible for preference of all claims and make good the damages or loss by way of repairs and / or replacement of the equipment, damaged or lost. All replacement of loss and damages to the equipment shall be made by the suppliers' / contractors' with no cost to TSECL.
If not taken back, the storage charges @ 2% per month of the cost of the returnable material shall be applicable.

33.0 DEMURRAGE, WHARFAGE, ETC.

- 33.1 All demurrage, wharf age and other expenses incurred due to delayed clearance of the material or any other reason shall be to the account of the Contractor.

34.0 FORCE MAJEURE

- 34.1 Force majeure is herein defined as any cause which is beyond the control of the Contractor or the Owner as the case may be, which they could not foresee or with a reasonable amount of diligence could not have foreseen and which substantially affects the performance of the Contract, such as:
- a. Natural phenomena, including but not limited to floods, droughts, earthquakes and epidemics;
 - b. Acts of any Government, domestic or foreign, including but not limited to war, declared or undeclared, priorities, quarantines, embargoes.

Provided either party shall within fifteen (15) days from the occurrence of such a cause notify the other in writing of such causes.

- 34.2 The Purchaser or the Owner shall not be liable for delays in performing his obligations resulting from any force-majeure cause as referred to and/or defined above. The date of completion will, subject to hereinafter provided, be extended by a reasonable time even though such cause may occur after Contractor's performance of obligation has been delayed due to other causes.

35.0 CONTRACTOR'S DEFAULT:

- 35.1 The Contractor shall have to pay liquidated damages for delay in completion of Works as defined in clause 14.0 of this Section.

The termination of the Contract under this clause shall neither entitle the Contractor to reduce the value of the Contract Performance Guarantee nor the time thereof. The Contract Performance Guarantee shall be valid for the full value and for the full period of the Contract including guarantee period.

36.0 TERMINATION OF CONTRACT ON OWNER'S INITIATIVE

- 36.1 The Owner reserves the right to terminate the Contract either in part or in full due to reasons other than those mentioned under clause entitled "Contractor's Default." The Owner shall in such an event give fifteen (15) days notice in writing to the Contractor of his decision to do so.
- 36.2 The Contractor upon receipt of such notice shall discontinue the work on the date and to the extent specified in the notice, make all reasonable efforts to obtain cancellation of all orders and contracts to the extent they are related to the work terminated and terms satisfactory to the Owner, stop all further sub-contracting or purchasing activity related to the work terminated, and assist the Owner in maintenance, protection, and disposition of the Works acquired under the Contract by the Owner.
- 36.3 In the event of such a termination, the Contractor shall be paid compensation, equitable and reasonable, dictated by the circumstances prevalent at the time of termination.
- 36.4 If the Contractor is an individual or a proprietary concern and the individual or the proprietor dies and if the Contractor is a partnership concern and one of the partners dies then unless the Owner is satisfied that the legal representatives of the individual contractor or of the proprietor of propriety concern and in the case of partnership, the surviving partners, are capable of carrying out and completing the Contract, the Owner shall be entitled to cancel the Contract as to its uncompleted part without being in any way liable to payment of any compensation to the estate of deceased Contractor and/or to the surviving partners of the Contractor's firm on account of the cancellation of the

Contract. The decision of the Owner that the legal representatives of the deceased Contractor or surviving partners of the Contractor's firm cannot carry out and complete the Contract shall be final and binding on the parties. In the event of such cancellation, the Owner shall not hold the estate of the deceased Contractor and / or the surviving partner of the Contractor's firm liable to damages for not completing the Contract.

37.0 GRAFTS AND COMMISSIONS ETC.

Any graft, commission, gift or advantage given, promised or offered by or on behalf of the Contractor or his partner, agent, officers, director, employee or servant or any one on his or their behalf in relation to the obtaining or to the execution of this or any other Contract with the Owner, shall in addition to any criminal liability which it may incur, subject the Contractor to the cancellation of this and all other contracts and also to payment of any loss or damage to the Owner resulting from any cancellation. The Owner shall then be entitled to deduct the amount so payable from any monies otherwise due to Contractor under the Contract.

38.0 SETTLEMENT OF DISPUTES

- 38.1 Any dispute(s) or difference (s) arising out of or in connection with the Contract shall, to the extent possible, be settled amicably between the parties.
- 38.2 If any dispute or difference of any kind whatsoever shall arise between the Owner and the Contractor, arising out of the Contract for the performance of the Works whether during the progress of the Works or after its completion or whether before or after the termination, abandonment or breach of the Contract, it shall, in the first place, be referred to and settled by the Engineer, who, within a period of thirty (30) days after being requested by either party to do so, shall give written notice of his decision to the Owner and the Contractor.
- 38.3 Save as hereinafter provided, such decision in respect of every matters so referred shall be final and binding upon the parties until the completion of the Works and shall forthwith be given effect to by the Contractor who shall proceed with the Works with all due diligence, whether he or the Owner requires arbitration as hereinafter provided or not.
- 38.4 If after the Engineer has given written notice of his decision to the parties, no claim to arbitration has been communicated to him by either party within thirty (30) days from the receipt of such notice, the said decision shall become final and binding on the parties.
- 38.5 In the event of the Engineer failing to notify his decision as aforesaid within thirty (30) days after being requested as aforesaid, or in the event of either the Owner or the Contractor being dissatisfied with any such decision, or within thirty (30) days, after the expiry of the first mentioned period of thirty (30) days, as the case may be, either party may require that the matters in dispute be referred to arbitration as hereinafter provided.

39.0 REGULATION OF LOCAL AUTHORITIES

- 39.1 The Contractor shall comply with all the rules and regulations of local authorities during the performance of his execution activities. He shall also comply with the Minimum Wages Act, 1948 and the Payment of Wages Act (both of the Government of India) and the rules made there-under in respect of any employee or workman employed or engaged by him or his Sub-Contractor.
- 39.2 All registration and statutory inspection fees, if any, in respect of his work pursuant to this Contract shall be to the account of the Contractor. However, any registration, statutory inspection fees lawfully

payable under any statutory laws and its amendments from time to time during installation & commissioning in respect of the equipment ultimately to be owned by the Owner, shall be to the account of TSECL. Should any such inspection or registration need to be re-arranged due to the fault of the Contractor or his Sub-Contractor, the additional fees to such inspection and/or registration shall be borne by the Contractor.

40.0 OWNER'S LIEN ON EQUIPMENT

TSECL shall have a lien on all equipment including those of the Contractor brought to the Site for the purpose of installation, testing and commissioning of the equipment, machine(s), other Hardware to be supplied & installed under the Contract. TSECL shall continue to hold the lien on all such equipment throughout the period of Contract. No material brought to the Site shall be removed from the Site by the Contractor and/or his Sub-Contractors without the prior written approval of the Engineer.

41.0 Safety Rules:

- 41.1 a) Each employee shall be provided with initial indoctrination regarding safety by the Contractor, so as to enable him to conduct his work in a safe manner.
 - b) No employee shall be given a new assignment of work unfamiliar to him without proper introduction as to the hazards incident thereto, both to himself and his fellow employees.
 - c) Under no circumstances shall an employee hurry or take unnecessary chance when working under hazardous conditions.
 - d) Employees under the influence of any intoxicating beverage, even to the slightest degree shall not be permitted to remain at work.
 - e) There shall be a suitable arrangement at every work site for rendering prompt and sufficient first aid to the injured.
- 41.2 The Contractor shall follow and comply with all relevant Safety Rules, relevant provisions of applicable laws pertaining to the safety of workmen, employees, plant and equipment as may be prescribed from time to time without any demur, protest or contest or reservation. In case of any discrepancy between statutory requirement and relevant Safety Rules referred above, the later shall be binding on the Contractor unless the statutory provisions are more stringent.
- 41.3 If the Contractor does not take all safety precautions and/or fails to comply with the Safety Rules as prescribed by Consortium or under the applicable law for the safety of the equipment and plant and for the safety of personnel and the Contractor does not prevent hazardous conditions which cause injury to his own employees or employees of other contractors, or Employees of TSECL or any other person who are at Site or adjacent thereto, the Contractors shall be responsible for payment of compensation to Consortium members as per the compensation order issued by the appropriate authority of Government of Tripura / verdict issued by court.

The compensation mentioned above shall be in addition to the compensation payable to the workmen / employees under the relevant provisions of the Workmen's Compensation Act and rules framed there under or any other applicable laws as applicable from time to time. In case TSECL is made to pay such compensation then the amount of such compensation shall be deducted from the progressive bills / contract performance guaranty of the contractor.

+++++

SECTION-IV

Technical specifications for **63 KVA BIS (Label-2) outdoor type three phase, 11 KV / 433-250V, Distribution Transformer** conforming to **IS : 1180-2014 and IS : 2026 as amended latest.**

1.0 SCOPE :

This specification covers the design, manufacture, testing at works, supply/ delivery & transportation of oil immersed, naturally air cooled (type ONAN), three-phase, 50 Hz, 11/0.433-0.250 KV step down, double-wound, outdoor non sealed type Distribution Transformer of capacity **63 KVA** as per IS : 1180-2014 and IS : 2026 as amended latest F.O.T. at Electrical Stores Division, A. D. Nagar, Agartala.

1.1 TYPE :

- i) The transformers shall be double wound, three phase, oil immersed, oil natural air natural cooled (type 'ONAN'), core type suitable for outdoor installation and shall be insulated with DPC insulation on HV & LV windings. Insulation should be of temperature class as per the temperature rise stipulated in this specification.
- ii) The neutral point of the secondary (LV winding) is intended for solidly earthed system and should be brought out to a separate insulated terminal.

1.2 STANDARD RATINGS :

Standard Ratings	63 KVA
System voltage (max.)	12 kV
Rated voltage HV	11 kV
Rated voltage LV	433 - 250 V*
Frequency	50 Hz. Subject to fluctuation of $\pm 5\%$.
No. of Phases	Three
Connection HV	Delta
Connection LV	Star (Neutral brought out)
Vector group	Dyn-11
Type of cooling	ONAN
No Load Voltage ratio	11000 / 433-250 Volts
Rated basic insulation level	75 KVp as per IS- 1180(Part-I) : 2014.

2.0 Winding Connections and Phase displacement :

The primary windings of the transformers shall be connected in delta and the secondary windings in star **vector symbol, Dyn-11], so as to produce , a positive phase displacement of 30° from the primary to secondary vectors of the same phase.** The neutral of the secondary winding shall be brought out to a separate insulated terminal.

3.0 Taps :

No tapings shall be provided for transformer upto & i/c 100 KVA rating.

4.0 STANDARDS

The transformer/materials shall conform in all respect to the relevant Indian/International Standard Specification, with latest amendments thereof as guided in IS : 1180-2014 and IS : 2026 as amended latest some of them are listed below:

IS No.	Title
191:2007	Copper
335:1993	New insulating oils
554:1999	Pipe Threads Where Pressure-Tight Joints are made on the Threads Dimensions, Tolerances and Designation
1576:1992	Solid press board for electrical purpose
1608:2005	Mechanical testing of metals-tensile Testing
1747:1972	Nitrogen
1885(Part 38):1993	Electro-technical vocabulary: Part 38 Power transformers and reactors
1897:2008	Copper strip for electrical purpose
2026	Power transformers:
(Part 1):2011	General
(Part 2):2010	Temperature rise
(Part 3):2009	Insulation levels, dielectric tests and external clearances in air
(Part 5):2011	Ability to withstand short circuit
(Part 8):2009	Application guide
(Part 10):2009	Determination of sound levels
2099:1986	Bushings for alternative voltages above 1000Volts
3024:2006	Grain oriented electrical steel sheets and strips
3347	Dimensions for porcelain transformer bushings for use in lightly Polluted Atmospheres
(Part1/Sec1):1979	Part1: Up to and including 1kV: Section 1 Porcelain parts
(Part1/Sec2):1979	Part1: Up to and including 1kV: Section 2 Metal parts
(Part2/Sec1):1979	3.6kV Bushings: Section 1 Porcelain parts
(Part2/Sec2):1979	3.6kV Bushings: Section 2 Metal parts
(Part3/Sec1):1988	17.5kV Bushings: Section 1 Porcelain parts
(Part3/Sec2):1988	17.5kV Bushings: Section 2 Metal parts
(Part4/Sec1):1988	24kV Bushings: Section 1 Porcelain parts
(Part4/Sec2):1982	24kV Bushings: Section 2 Metal parts
(Part5/Sec1):1979	36kV Bushings: Section 1 Porcelain parts
(Part5/Sec2):1979	36kV Bushings: Section 2 Metal parts
3639:1966	Fittings and accessories for Power Transformers
4253(Part 2): 2008	Cork composition sheet- Part 2 Cork and Rubber
6162	Paper covered aluminium conductors Round conductors
(Part 1): 1971	

6162(Part 2): 1971	Rectangular conductors
7404(Part 1): 1991	Paper covered copper conductors: Part 1 Round conductors
7421:1988	Porcelain bushings for alternating voltages up to and including 1000V
8999:2003	Pipe Threads Where Pressure-Tight Joints are made on the Threads Verification by Means of Limit Gauges
9335	Cellulosic papers for electrical purposes: Definitions and general requirements
(Part 1): 1979	
(Part 2): 1998	Methods of test
(Part3/Sec1):1984	Specifications for individual materials, Section 1 General purposes electrical paper
(Part3/Sec3):1984	Specifications for individual materials, Section 3 Crepe paper
(Part3/Sec5):1985	Specifications for individual materials, Section 5 Special paper
11149:1984	Specifications for rubber gaskets
12444:1988	Continuously cast and rolled electrolytic copper wire rods for electrical conductors
13730(Part 0/Sec3): 2012	Specifications for particular types of winding wires: General requirements Section 3:Enameled round copper wire,
(Part 17):1996	Polyvinyl acetal enameled rectangular copper wire, Class 105
(Part 27):1996	Paper covered rectangular copper wire
16081:2013	Insulating liquids- Specification for unused synthetic organic esters for electrical purposes

5.0 CLIMATIC CONDITIONS:

The Distribution Transformers to be supplied against this Specification shall be suitable for satisfactory continuous operation under the following climatic conditions as per IS : 1180-2014 and IS : 2026 as amended latest.

- i. Location: At various locations in Tripura.
- ii. Max. ambient air temperature (Deg⁰ C): 50⁰C
- iii. Maximum relative humidity: 95% (sometime approaches Saturation point)
- iv. Max. Altitude above mean sea level(Meters): 1000 M.

6.0 LIMITS OF TEMPERATURE RISE:

6.1 The type of cooling shall be ONAN as per IS : 1180-2014 and IS : 2026 as amended latest.

6.2 The permissible temperature rise shall not exceed the limits of when measured by resistance method for transformer winding and measured by thermometer for top oil when tested in accordance with IS: 2026(Part-2) :

KVA Rating	for transformer winding (when measured by resistance method)	for top oil (by thermometer)
Upto 3-ph 200 KVA	40°C	35°C

7.0. DESIGN AND CONSTRUCTION :

7.1 Core :

7.1.1 Material : CRGO Sheet

- 7.1.2. The core shall be of NEW high grade cold rolled grain annealed steel lamination having low loss and good grain properties, coated with hot oil proof insulation, bolted together and to the frames firmly to prevent vibration or noise. **All core clamping bolts, MS hardwares etc. inside the tank shall be effectively insulated** The complete design of core must ensure permanency of the core losses with continuous working of the transformers.
The grade of core laminations shall be M4 or better.

N.B 1: The successful bidder shall be required to submit the manufacturer's test report Showing the Watt loss per Kg and the thickness of the core lamination to ascertain the quality of core materials.

The purchaser reserves the right to get sample of the core material tested at any Government recognized laboratory.

Core Clamping for CRGO :

1. MS channel shall be used on top and bottom
2. Core Channel on LV side to be reinforced at equidistance, if holes / cutting is done for LT lead in order to avoid bending of channel.
3. MS Channels shall be painted with varnish or oil-resistant paint.

7.1.3. Details of Core :

- i. The core shall be stack type. The assembled core shall be securely clamped and bolted together, firmly to the frames to prevent vibration or noise.
- ii. The values of Audible sound level (decibels) at rated voltage and frequency for oil immersed distribution transformer (as per NEMA standard) is given below:

Sl no	KVA rating	Audible sound level (decibels)
i.	0 – 50	48
ii.	51 – 100	51
iii.	101 – 300	55
iv.	301 - 500	56

- iii. The core clamping frame shall be provided with lifting eyes for the purposes of tanking and un-tanking of the live parts of the transformer. The whole core shall be electrically connected by copper strip of adequate section to the core frame at two separate points for being eventually earthed through the tank to drain off electrostatic potential that may built up. Core top and bottom of yoke shall be supported with M.S. Channel of proper size and Properly bolted together for stack type core.
- iv. Adequate provision shall be made to prevent movement of the core and winding relative to the tank during transport and installation or while in service.

- v. Top & bottom yoke should be constructed as per drawing & design of the manufacturer but the core losses & magnetizing current should be guaranteed.
- vi. All channels, top and bottom yoke, Nut Bolts, Tie rods shall be painted with Hot resistant paint / varnish before use.
- vii. The cores shall conform to IS: 649 (testing for steel sheets & strips & magnetic circuit).

7.1.4. The transformer core shall not be saturated for any **value of V/ f ratio** to the extent of 112.5% of the rated value of V/f ratio (**i.e. 11 KV/50 due to combined effect of voltage and frequency**) upto 112.5% on any tapping without injurious heating at full load condition and will not get saturated. In support the supplier shall furnish necessary design data.

7.1.5. Flux Density :

The maximum flux density in any part of the core **shall not exceed 1.9 Tesla** for Distribution Transformer upto & i/c 3-ph 2500 KVA **as per IS 1180-2014 with latest amendment** .
The value of the maximum flux density allowed in the design and grade of lamination used shall be clearly stated in the offer.

The vendor shall furnish necessary design data in support of this stipulation. Tenderer should submit Maximum flux density & Core-weight calculation sheet.

7.1.6. No load current :

No load current at rated voltage and at 112.5% of rated voltage shall not exceed the values given below:

KVA Rating	Percentage of rated full load current	
	At 100 % rated voltage	At 112.5 % rated voltage
Upto 3-ph 200 KVA	3% of Full load current.	6% of Full load current

7.2 Winding :

7.2.1 Materials:

- Super Enamel covered **Aluminium** conductor shall be used for HV and
- Double paper covered **Aluminium** conductor shall be used for LV winding for 11 kV class and 22 kV class distribution transformers.

7.2.2 Current Density :

Current density for HV and LV winding should not be more than -

- 1.6 A / sq.mm for Aluminium conductor.

7.2.3 LV Winding shall be in even layers so that the neutral formation will be at top.

7.2.4 Inter layer insulation shall be Manila paper / dotted Kraft Paper insulation should be used.

7.2.5 Proper bonding of inter layer insulation with the conductor shall be ensured. Test for bonding strength shall be conducted.

7.2.6 The core / coil assembly shall be securely held in position to avoid any movement under short circuit conditions.

7.2.7 Bracing of Windings :

- i. The windings and connections shall be braced to withstand shocks which may occur during transport or due to switching / short circuit and other transient conditions during service.
- ii. Coil clamping rings, if provided, shall be of steel or of suitable insulating material. Axially laminated material other than bakelite paper shall not be used.
Transformer shall be provided with the requisite number of windings and shall be designed to withstand the electromechanical stress exerted under short circuit conditions as per ISS: 2026 – 1977.
- iii. Class ‘A’ insulation shall be used. Paper insulation shall be dry and uniform and free from punctures and other defects. Solid insulation shall be of best quality. Wooden supports, if used, shall be well seasoned and compatible with hot transformer oil. The test certificate of the raw materials shall be made available by the transformer manufacturer on request during Inspection & Testing.
- iv. The winding shall be so designed to reduce to a minimum the out of balance forces in the transformer at all voltage ratings.
- v. The winding shall also be designed such that all coil assemblies of identical voltage rating shall be interchangeable and repairing of the winding can be made readily without special equipments.
- vi. The winding shall be so designed to reduce to a minimum the out of balance forces in the transformer at all voltage ratings.
The winding shall also be designed such that all coil assemblies of identical voltage rating shall be interchangeable and repairing of the winding can be made readily without special equipments.

7.3.1. Losses and Impedance:

The bidder should guarantee individual no-load and load loss without any positive tolerance. The bidder should also guarantee the total losses at 50% and 100% load condition (at rated voltage and frequency and at 75° C without any positive tolerance).

Rating in KVA	Maximum Total Losses (in watts) at		Impedance (%) at 75° C
	50 % Loading	100 % Loading	
16	135	440	4.5%
25	190	635	4.5%
63	340	1140	4.5%
100	475	1650	4.5%
200	780	2300	4.5%

No Positive tolerance shall be allowed on the maximum losses displayed on the label for both **50%** and **100 %** loading values. In case, the actual loss values exceed the above guaranteed values, the transformers shall be rejected at the risk, cost and responsibility of the

supplier. The values guaranteed in G.T.P. for flux density, no load current at rated voltage, no load current at 112.5% of rated voltage and no load loss at rated voltage shall be individually met.

However, the bidder must indicate in GTP the No load loss & Load loss for evaluation as per formula given.

7.3.2. Bids will be evaluated as per the loss evaluation formula given in **REC, K-5 Standard** as amended upto date. Loss capitalization factor shall be taken as follows:

- i. Iron Loss (No load loss factor) : Rs. 4,82,900.00 / KW ;**
- ii. Copper Loss (Load loss factor) : Rs. 1,57,000.00 / KW ;**

7.4.0 Clearance inside the tank (for stack type core construction):

7.4.0 Insulation material and Clearance:					
Sl no	Particulars	KVA ratings			
		25	63	100	200
7.4.1	Radial clearance of LV coil to core (bare conductor) shall not be less than	3.5 mm	3.5 mm	4.0 mm	4.0 mm
7.4.2	Radial clearance between HV & LV shall not be less than	11 mm	11 mm	10.0 mm	10.0 mm
7.4.3	Phase to phase clearance between HV conductor shall not be less than	10 mm with the minm of 2 x 1 mm press board to cover the rods.	10 mm with the minm of 2 x 1 mm press board to cover the rods.	10.0 mm	10.0 mm
7.4.4	Minimum electrical clearance between the winding and body of the tank (between inside surface of the tank and outside edge of the windings) should be	30 mm	30 mm	30 mm	30 mm
7.4.5	Minimum end insulation to earth shall be	25 mm	25 mm	25 mm	25 mm
7.4.6	No. of coils HV & LV / phase (minimum)				
	HV =	4 nos	4 nos	4 nos	6 nos
	LV =	1 no	1 no	1 no	1 no
7.4.7	Minimum thickness of locking spacers between HV coils	10 mm	10 mm	10 mm	10 mm
7.4.8	No. of axial wedges between LV and HV winding equal-spaced around LV	6 nos	6 nos	8 nos	
7.4.9	Minimum external clearances of Bushing terminals				
	HV : Phase to Phase =	255 mm	255 mm	255 mm	255 mm
	HV : Phase to Earth =	140 mm	140 mm	140 mm	140 mm
	LV : Phase to Phase =	75 mm	75 mm	75 mm	75 mm
	LV : Phase to Earth =	40 mm	40 mm	40 mm	40 mm

7.5.0. TRANSFORMER TANK

7.5.1. Construction :

TANK - The shape of the tank shall be rectangular only. No other shape will be accepted. The tank shall be fabricated by welding at corners. No Horizontal or vertical joints in tank side and its bottom or top cover will be allowed.

For non-sealed or sealed type transformer, transformer tank can be of plain tank configuration with/without radiator or cooling tubes. The transformer tank covers shall be bolted / clamped alternatively welded with tank rim so as to make a leak proof joint. The curb design in case of welded construction shall be such that it is possible to remove the weld and reweld the tank at least two ties.

- (a) The tank design shall be such that the core and windings can be lifted freely.
- (b) The tank plate shall be of such strength that the complete transformer when filled with oil may be lifted easily by means of the lifting lugs provided.
- (c) Top cover shall be slightly sloping (difference of heights should be $20\text{mm} \pm 10\%$ towards H.V. bushing). Ends of cover plate should be bent to 90 degrees to avoid entry of water through cover plate gaskets and cover the top with end walls.
- (d)
 - i. Side wall plate thickness: **$3.15\text{ mm} \pm \text{Tolerance as per relevant IS:1852}$** .
 - ii. Top and bottom plate thickness: **$5.0\text{ mm} \pm \text{Tolerance as per relevant IS:1852}$** .
- (e) For transformers upto 200 KVA plain tank shall be capable of withstanding a pressure of 80 KPa and a vacuum of 250 mm of mercury. Limiting values of the deflections are specified in 21.5.1. of IS- 1180: 2014.
- (f) The transformer tank shall be of adequate mechanical strength to withstand positive and negative pressures built up inside the tank while the transformer is in operation.
- (g) Reinforced by welded angle of size 40x40x6 mm on all the outside walls of tank to form two equal compartments. One face of reinforcement angle should be continuous welded with the tank surface such that other side of the angle forms inverted "L".
- (h) The permanent deflection is not more than 5 mm upto 750 mm length, 6.5 mm upto 1250 mm length and 8.0 mm upto 1750 mm length when transformer tank without oil is subjected to a vacuum of 760 mm. of mercury.
- (i) Lifting Lugs : 2 Nos. welded heavy duty lifting lugs of M.S. Plate 8 mm. thick suitably reinforced by vertical supporting flat welded edgewise below the lug on the side wall.
- (j) Pulling Lug: 4 Nos. of welded heavy duty pulling lugs of M.S. Plates of 8 mm thick shall be provided on length side to pull the transformers horizontally.
- (k) Top cover Gasket & Bolts:
 - (i) Gaskets wherever used shall conform to Type III as per IS 11149/Type C as per IS 4253.
 - (ii) GI Nut Bolts :- All bolts/nuts/washers exposed to atmosphere shall be as follows:
 - a) Size 122 mm or below – stainless steel
 - b) Above 12 mm – steel with suitable finish like electro galvanized with passivation or hot dip galvanized.

(iii) The height of the tank shall be such that the minimum clear height upto the Top Cover Plate of 30 mm. clearance is achieved from the topmost live part of the tap changer.

- 7.5.2 (a) Heat dissipation by tank walls excluding top and bottom- Tenderer should submit the calculation sheet.
- (b) Heat Dissipation by fin type radiator will be worked out on the basis of manufacturers' data sheet. Tenderer should submit the calculation sheet.
- (c) Radiators shall be provided on both sides. They should be fixed at right angle to the sides and not diagonally. If the number of radiators is 2, the radiator will be provided on the LV side. However, if the no. of radiator is more than 2 (on the basis of heat dissipation calculation sheet), then may be provided on both HV & LV sides.
- Heat dissipation calculation sheet is to be submitted by the bidder.

7.5.3 Inside of tank shall be painted with varnish or oil resistant paint. For external surface coat of thermo setting powder paint or one coat of epoxy primer followed by two coat polyurethane base paint shall be used. Table given below shall be referred to for paint thickness for normal / medium corrosive atmosphere For highly polluted atmosphere and special application external paint transformer manufacturer.

Table of paint scheme for Distribution Transformer
(Refer to Clause 15.1 of IS : 1180-2014)

Sl. No	Paint Type	Area to be painted	No. of coats	Total Dry Film Thickness (Min Micron)
i.	Thermo setting powder paint	Inside	01	30
ii.	Liquid paint	Outside	01	60
	a) Epoxy (primer)	Outside	01	30
	b) Polyurethane(finish coat)	Outside	02	25 each
	c) Hot resistant paint /varnish	Inside	01	35 / 10

7.6.0 CONSERVATOR FOR NON-SEALED TYPE TRANSFORMER

- 7.6.1 Transformers of ratings 63 KVA and above with plain tank construction, the provision of conservator is mandatory.
- 7.6.2 When a conservator is provided, oil gauge and the plan or dehydrating breathing device shall be fixed to the conservator which shall also be provided with a drain plug and a filling hole (1 1/4" normal size thread) with cover. The capacity of a conservator tank shall be designed keeping in view the total quantity of oil and its contraction and expansion due to temperature variations. In addition, the cover of main tank shall be provided with an air release plug to enable air trapped within to be released, unless the conservator is so located as to eliminate the possibility of air being trapped within the main tank.
- 7.6.3 The inside diameter of the pipe connecting the conservator to the main tank should be 25 to 50 mm and it should be projected into the conservator so that its end is at least 20 mm above the bottom of the conservator so as to create a sump for collection of impurities. The minimum oil level corresponding to 5° C should be above the sump level.

7.7 Breather: Breather joints will be screwed type. It shall have die-cast Aluminium body. Inside container for silicagel will be of tin sheet. Make of breathers shall be subject to purchaser's approval. Volume of breather shall be suitable for **500 gm (Minimum)** of Silicagel.

7.8 Terminals:

- (i) **Brass** rods of **12 mm** dia. for **H.T.** with necessary Nuts, check nuts and plain thick tinned washers.
- (ii) **L.T. terminal** shall be manufactured with necessary nuts, check nuts and plain thick tinned washers in accordance with relevant IS with latest amendment.

7.9. Bushings :

(i) For 11 KV- 12 KV Bushing will be used and for 433 volts 1.1 KV terminal bushing will be used. Bushings of the same voltage class shall be interchangeable. Bushings with plain sheds as per IS - 3347 shall be mounted on side of the tank and not on the top cover. Only continuous sheet metal pocket shall be provided for mounting of all **L.V.** bushings and the same shall not be fixed on pipes. Sheet metal pocket shall be designed in such a way that all HT bushings shall remain parallel and **equidistant** all through and inside connections of winding to bushings shall remain within the pocket. Bushings having been type tested as per IS-3347 shall only be acceptable.

(ii) Internal Connections: - In case of HV winding, all jumpers from windings to bushing shall have cross section larger than the winding conductor (normally, 1.5 times). Alternatively joints will be made by using tubular connectors properly crimped at three spots.

LT star connection will be made by using Aluminium Flat and properly brazed or bolted with crimped lugs on winding by means of plain or spring washers and lock nuts to the flat. Other end of the conductor is brazed on "EL" shape Aluminium flat and flat nut bolted with neutral bushing Stud. The star connection should be wrapped with cotton / paper tape.

Firm connection for LV winding to bushings shall be made by adequate size of "EL" shape flat, nut bolted with LV Bushing stud.

SRBP tube / insulation paper should be used for delta connection and on the portion of HV winding joining to HV bushing.

7.10 Rollers:- No roller is required for Transformers of rating 63 KVA.

7.11 Tank Base Channel: To be fitted across the length of the transformer.

- i. For 16 KVA Transformer - Two channels of 75 mm x 40 mm.
- ii. For 25 KVA Transformer - Two channels of 75 mm x 40 mm.
- iii. For 63 KVA Transformer - Two channels of 75 mm x 40 mm.**
- iv. For 100 KVA Transformer - Two channels of 75 mm x 40 mm.
- v. For 200 KVA Transformer - Two channels of 100 mm x 50 mm.

7.12 ABILITY OF TRANSFORMERS TO WITHSTAND EXTERNAL SHORT CIRCUIT

The performance of transformer under external short-circuit conditions shall be in accordance with IS 2026 (Part 5).

7.13 EFFICIENCY AND REGULATION :

When statement of efficiency and regulations are required they shall be based on specified loading at the rated KVA and unity power factor and computed in accordance with Annex B and Annex C respectively.

7.14 TOLERANCE

The tolerance on electrical performance excluding losses shall be allowed as per IS 2026(Part-I).

7.15.0 FITTINGS

7.15.1 Standard Fittings (as per amendment no-1 to I.S. 1180 : 2014)

The following standard fittings shall be provided.

- a) Two earthing terminals with the earthing symbol =1
- b) Oil level gauge indicating oil level at minimum 30° C and maximum operating temperature.

NOTES

- Minimum and maximum positions correspond to the operating temperature of (-)5°C and 90°C respectively (for non-sealed type transformer).
- c) Air release device (for non-sealed type transformers)
 - d) Rating and terminal marking plates.
 - e) Plain breathing device for non-sealed type transformers which would not permit ingress of rain water and insects up to 200 KVA transformers.
 - f) Drain cum sampling valve ¾" nominal size thread, IS 554) preferably steel with plug for three phase transformer.
 - g) Thermometer pocket with cap
 - h) Oil filling holes having 1 ¼" nominal size thread) with cover (for sealed type transformers without conservator).
 - i) An extended pipe connection on upper end with welded cover for sealed type transformers The pipe should be suitably threaded over a sufficient length to enable use of a refilling/siphon connection after removing the welded cover or any other similar arrangement capable of reuse.
 - j) Lifting lugs for the complete transformer as well as for core and winding assembly
 - k) Nitrogen/air filling device/pipe with welded cover capable of reuse (for sealed type transformer)
 - l) HV side neutral grounding strip (where one of the HV bushing terminal is connected to earth).

7.15.2 Optional Fittings (as per amendment no-1 to I.S. 1180 : 2014)

The following shall be available as additional fittings at the option of the user wherever specified

- a) Dehydrating breather in lieu of plain breathing device for transformers up to 200 KVA
- b) Filter valve 1 ¼" nominal size thread) for transformers up to 200KVA
- c) Arching norms or suitable rating lightning arrestors for HT side – 3 Nos transformers upto 200 KVA
- d) Bird guard
- e) Terminal connectors
- f) Non return valve (for conducting pressure test)
- g) Pressure relief device or explosion vent (up to 200KVA)
- h) 4 No's anti-theft stainless steel fasteners with breakaway nut shall be provided at top cover (up to 200 KVA)

Note – IS 3639 describes some of the fittings and accessories.

7.16.0 TESTS

7.16.1 General

All routine type and special tests as described in 7.16.2 to 7.16.3 shall be performed as per relevant parts of IS 2026. Pressure and oil leakage test shall be conducted as per 7.16.4

7.16.2 Routine Tests (to be conducted on all units)

The following shall constitute the routine tests.

- a) Measurement of winding resistance IS 2026(Part I)
- b) Measurement of voltage ratio and check of phase displacement IS 2026(PartI)
- c) Measurement of short-circuit impedance (principal trapping, when applicable and load loss at 50 percent and 100 percent load IS 2026 (PartI)
- d) Measurement of no-load loss and current IS 2026(Part I)
- e) Measurement of insulation resistance IS 2026(Part I)
- f) Induced over-voltage withstand test IS 2026 (Part3)
- g) Separate source voltage withstand test IS: 2026(Part3)
- h) Pressure test (see 7.16.4)
- i) Oil leakage test (see 7.16.4)
- j) Temperature rise test IS: 2026 (Part -2)

Type Tests (to be conducted on one unit)

The following shall constitute the type tests :

- a) Lighting impulses test IS: 2026(Part-I)
- b) Temperature rise test IS: 2026 (Part -2)
Note: routine tests before and after circuit test shall be conducted as per IS 2026(Part-I)
- c) Short circuit withstand test IS: 2026(Part5) up to 200KVA
Note routine tests before and after short circuit test shall be conducted as per IS 2026 (Part)
- d) Pressure test (see 21.5)

7.16.3 Special Tests (to be conducted on one unit)

The following shall constitute the special tests which shall be carried out by manual agreement between the user and the supplier.

- a) Determination of sound levels IS 2026 (Part 10)
- b) Short-circuit withstand test IS: 2026(Part5)
Note : Routine test before and after short circuit test shall be conducted as per IS:2026(Part i)
- c) No load current at 112.5 percent voltage (see 5.9.3)
- d) Paint adhesion tests. The test is performed as per ASTM D3359 (Standard Test Methods) for measuring adhesion by Tape test)
- e) BDV and moisture content of oil in the transformer (IS 335)
Note : Test at d) and e) may be carried out on more than one unit subject to agreement between user and supplier.

7.16.4 Pressure and Oil leakage Test

For Transformer up to 200 KVA

Pressure test (type test)

For non-sealed and sealed type transformers, the transformer tank shall be subjected to air pressure of 80 kpa for 30 minutes and vacuum of 250 mm of Mercury for 30 minutes.

The permanent deflection of flat plates, after pressure / vacuum has been released, shall not exceed the value given below .

<u>Length of Plate</u>	<u>Deflection</u>
Upto 750 mm	5 mm
751 to 1 250mm	6.5 mm

Pressure (routine test)

- Non sealed type transformer (plain tanks) :

The transformer with bolted cover shall be tested at an air pressure of 35 ka above atmosphere pressure maintained inside the tank for 10 min. There should be no leakage at any point.

Oil leakage test (routine test)

The assembled transformer for non-sealed and sealed type with all fittings including bushing in position, shall be tested at a pressure equivalent to twice the normal head measured at the base of the tank for 8 h. There should be no leakage at any point.

7.17.0 INFORMATION REQUIRED WITH ENQUIRY AND ORDER

7.17.1 The information to be supplied by the manufacturer with enquiry and order to the purchaser shall be in accordance with Annex D.

7.19.0. RATING and TERMINAL MARKING PLATE:

i. The transformers shall be provided with rating plate made of anodized aluminium / stainless steel material securely fixed on the outer body, easily accessible, showing the information given in Fig. 1 as specified in Clause no 13.1 of IS : 1180-2014. The entries on the rating plate shall be indelibly marked by etching, engraving or stamping. This rating plate should cover the terminal marking in accordance with Fig 3 as specified in Clause no 13.1 of IS : 1180-2014.

ii. Further **M.S. plate of size 125mm x 125 mm** be got welded on width side of transformer on stiffener angle. On this plate, name of firm, order no. and date, rating, serial no. and date of dispatch should be engraved.

iii. Another plate shall be provided clearly and indelibly marked the BIS Certification Mark License No. (CM/L XXXXXXXXXXXX) and reference to BIS web site "For details of BIS certification marks scheme refer www.bis.org.in".

7.20. TRANSFORMER OIL:

The transformer shall be supplied complete with first filling of oil and the same shall comply with IS: 335 -1983 with latest version thereof and ageing characteristics specified. . These characteristics⁶ are shown in Annexure- A. Type test certificate of oil being used shall be produced at the time of inspection.

ANNEXURE-A

TECHNICAL PARTICULARS OF TRANSFORMER OIL

Sl. No	Characteristics	Requirements
A	NEW OIL	
1	Flash Point Pensky Marten (Closed)	140U
2	Neutralization value a) Total acidity, Max b) Inorganic acidity	a) 0.03 mg KQH/g b) NIL
3	Corrosive Sulfur	Non-corrosive
4	Electric Strength (breakdown voltage Min) a) New Unfiltered Oil b) New oil after filtration	30 KV (rms) 60 KV (rms)
5	Dielectric dissipation factor (tan delta) at 90° c	0.002
6	Specific resistance (resistivity) a) at 90°C Min. b) at 27°C Min	35x10 ¹² Ohm-cm 1500x10 ¹² Ohm-cm
7	Oxidation stability a) Neutralization value after oxidation, Max b) Total sludge after oxidation Max c) S.K. Value	0.40 mg KQH/g 0.10% by weight 4% to 8%
8	AGEING CHARACTERISTICS Ageing characteristics after accelerated ageing (open breaker method with copper catalyst) a) Specific resistance (resistivity) i) at 27°C ii) at 90°C	2.5x10 ¹² Ohm-cm (Min) 0.2x10 ¹² Ohm-cm (Min) 0.20 Max 0.05 Max 0.05% by weight (Max)

	b) Dielectric dissipation factor(Tan Delta) c) Total acidity in mg KgH/g d) Total sludge value	
B	CHARACTERISTICS OF OIL IN THE TRANSFORMER The important characteristics of the transformer oil after it is filled in the transformer (within 3 months of filling) shall be as follows :-	
1	Electric strength (breakdown voltage)	40 KV(Min.)
2	Dielectric dissipation factor Tan. Delta at 90 ⁰ C	0.01 (Max.)
3	Specific resistance (Resistivity)at 27 ⁰ C(Ohm-cm)	10 x10 ¹² Ohm-cm
4	Flash point ,PM.(closed)	140 ⁰ C (Min)
5	Interfacial tension at 27 ⁰ C	0.03 N/m (Min.)
6	Neutralization value (total acidity)	0.05mgQH/g(Max.)
7	Water content	35 PPM (Max.)

7.21 Purchaser reserves the right to get all or any type test carried out on at least one sample for each rating of transformer at the cost of supplier from **CPRI-Bangalore or ERDA**, Vadodara without any extra time.

7.22 ACCEPTANCE TEST:- The following tests shall be witnessed by the Purchaser's Representative at the works of manufacturer :

- (i) All the routine tests as mentioned in clause 12.1 shall be performed on minimum 10% quantity of offered lot.
- (ii) Heat run test - One unit of the ordered quantity.
- (iii) Verification of active parts on one unit of each rating of ordered quantity along with total weight of one unit.
One unit of each rating offered shall be dismantled at the time of pre-despatch inspection for physical verification for constructional details.
- (iv) Further, the Purchaser's Inspector reserves the right to get the Spill Current Measurement Test and also the Pressure Test performed on any tank during his inspection.

7.23 TESTING FACILITIES :- The tenderer should have adequate testing facilities for all routine and acceptance tests and also arrangement for measurement of losses, resistance etc.

7.24 TEST AND INSPECTION :

Stage Inspection : Transformer plays a crucial role in the Power Distribution network and any failure creates disruption of power supply to consumers and the extent of effect depends upon the quality during manufacturing process.

To maintain the quality of manufacturing process, the purchaser reserves the right to conduct stage inspection during manufacturing at works. Unless and until stage inspection is being conducted or waiver of stage inspection is being cleared, the pre-despatch inspection call shall not be taken into consideration. To ensure about the quality of transformers, the inspection may be carried out by the Purchaser's representative at following two stages :

- (i) When raw material is received, and the assembly is in process in the shop floor.*
- (ii) At finished stage i.e. transformers are fully assembled and are ready for dispatch.*

The manufacturer should give prior importance on the following details before the process of assembling and the same shall be verified at the time of stage inspection. The matter should be treated as essential criteria during stage inspection.

- a) After the main raw materials i.e. core and coil materials and tanks are arranged and transformers are taken for production on shop floor and a few assemblies have been completed, the firm shall intimate in this regard, so that inspector(s) for carrying out such inspection could be deputed, as far as possible within 15 days from the date of intimation. During the stage inspection a few assembled core shall be dismantled to ensure that the CRGO laminations (M4 or better) used are of good quality. Further, as and when the transformers are ready for dispatch, an offer intimating about the readiness of transformers, for final inspection' for carrying out tests as per relevant I.S.S. and as in clause 12 & 15, shall be sent by the firm along with Routine Test Certificates. The inspection shall normally be arranged at the earliest after receipt of offer for pre-delivery inspection.
- b) In case of any defect/defective workmanship observed at any stage by the Inspecting Officer, the same shall be pointed out to the firm in writing for taking remedial measures. Further processing should only be done after clearance from the Inspecting Officer/Purchaser.
- c) All tests and inspection shall be conducted out at the place of manufacture unless otherwise specifically agreed upon by the manufacturer and purchaser at the time of purchase. The manufacturer shall offer the Inspector representing the Purchaser all reasonable facilities, without charges, to satisfy him that the material is being supplied in accordance with this specification. This will include Stage Inspection during manufacturing stage as well as Active Part Inspection during Acceptance Tests.
- d) Random sample checking and testing of the transformer selected at random from the supplies made to the Stores, shall be done for verification of technical details, design and losses as per approved drawings and technical particulars and specification of the order. In case of variations, the lot shall be rejected.
- e) The Purchaser has all the rights to conduct any test at his own cost by an independent agency whenever there is dispute regarding the quality of supply or interpretation of test results. However, in the event of failure of transformers in such tests, the expenses incurred in testing shall be to the Supplier's account.

f) A quantity of more than 100 Nos. shall not be entertained for stage inspection. Further, the stage inspection shall be carried out in case :

- At least 25% quantity offered has been tanked, and Core Coil Assembly of further at least 30 % of the quantity offered has been completed.
- Quantity offered for stage inspection should be offered for final inspection in full within 15 days from the date of issue of clearance for stage inspection, otherwise stage inspection already cleared shall be liable for cancellation.
- Quantity offered for stage inspection should be offered for final inspection in full within 15 days from the date of issue of clearance for stage inspection, otherwise stage inspection already cleared shall be liable for cancellation.

7.25. INSPECTION & TESTING OF TRANSFORMER OIL:

To ascertain the quality of the transformer oil, the original manufacturer's test report should be submitted at the time of inspection. Also arrangements should be made for testing of transformer oil, after taking out the sample from the manufactured transformers and tested in the presence of purchaser's representative.

7.26. TEST REPORTS ON THE ANALYSIS OF RAW MATERIAL:

The supplier shall furnish details of source(s) of raw materials, test certificates and report on the analysis of electrolytic copper/Aluminium used for the winding and the steel used for core, insulation material and also other bought out items from sub-suppliers.

7.27. DRAWINGS:

The General Arrangement dimensional drawing and Core Coil Assembly Drawing showing internal construction of each rating of transformer shall be submitted with the tender. Guaranteed and other technical particulars of the transformers should also be submitted in A-4 size for approval.

7.28. PACKING

Transformer shall be delivered suitably packed. Although the method of packing is left to the discretion of the manufacturer it should be robust enough for rough handling that is occasioned during transportation by road.

All accessories shall be dispatched in boxes or cases. They shall be securely bound with wire and shall have all descriptive marking stamped thereon.

7.29. GUARANTEED TECHNICAL PARTICULARS

The guaranteed technical particulars of the distribution transformer offered, shall be given by the bidder in the schedule annexed in the bid document by the bidder along with the tender.

GURANTEED TECHNICAL PARTICULARS FOR 63 KVA BIS (label-2) certified DISTRIBUTION TRANSFORMER

Sl.No	Particulars	N.I.T. requirement	Bidders' offer
1	Continuous Max. Rating (KVA)	63 KVA	
2	Normal Ratio of Transformer	11 / 0.433 - 0.250 KV	
3	Method of connection	Vector Group : Dyn-11	
4	Max. Hot spot temp	ambient air temperature shall be taken as 50 ^o C	
5	Max.Top Oil temp above ambient temperature	35 ^o C	
6	Max. Winding temp above ambient temperature	40 ^o C	
7	Flux density	Shall not exceed 1.9 Tesla for Distribution Transformer upto 3-ph 2500 KVA.	
8	Type of transformer	Core type	
9	CORE		
a)	Core Material & Grade	CRGO, Grade – M4 or better	
b)	No of CRGO lamination piece in which top & bottom yoke is proposed to be constructed		
c)	No. of steps		
d)	Dimensions of core steps i) Gross ii) Effective		
e)	Core area i) Gross ii) Effective		
f)	Core Diameter		
g)	Core length (leg centre)		
h)	Window Height		
i)	Insulation between bottom of core & base channel		
j)	Size of core base channel (Cut channels are not acceptable)		
k)	Core height (inclusive of base channel and insulation in between)		
l)	No. & dimensions of steel channel used for clamping of core		
m)	Size & No. of :- i) Core bolts ii) Tie rods		
n)	Insulation of core bolts i) Core bolts ii) Tie bolts		
o)	Painting of : i) Core Channel ii) Core bolt iii) Tie rod		
p)	Whether top yoke is cut or holes are made for LV connectors. If yes, whether enforcement is done		

9.g)	Weight of Core (without channels)		
10	Magnetizing current(% of rated current) a) at 90 % Voltage b) at 100 % Voltage c) at 112.5 % Voltage d) Tolerance		
11	Current Density	should not be more than 1.6 A / sq. mm for Aluminium conductor.	
12	WINDINGS: a) Material	<ul style="list-style-type: none"> • HV winding shall be wound from Super Enamel Covered aluminium conductor for 16, 25 & 63 KVA <li style="text-align: center;">and • LV winding shall be wound from Double paper Covered aluminium conductor for 16,25,63 & 100 KVA . <p>Foil winding will not be acceptable.</p>	
	b) Size of winding wires for i) H.T. ii) L.T		
	c) Type of Insulation of i) HV winding ii) LV winding		
	d) Internal & external dia. of i) HV coil ii) LV coil		
	e) No. of Coils / Phase i) HV ii) LV	i) HV = 4 nos; ii) LV = 1 no.	
	f) No. of turns per coil i) HV ii) LV		
	g) Height of i) LV coil ii) HV coil		
	h) Method of connection of winding ends to bushing terminals:	i) For HV- The ends of windings brazed with copper wire. Other end of copper wire should be bolted with HV stud by forming loop and using washer. ii)For LV- Other end of LV winding should be crimped with lugs (identical metal) and then bolted with LV stud terminals by using EL shaped Al. Flat. iii) Method of forming star connection—	

		<p>All the three ends of LV windings should be crimped with proper size of lugs (identical metal) and then bolted with Al flat 6 mm thick.</p> <p>(In place of using nut bolt system, brazing is proposed to be done for (i) & (ii) above, the same may please be clearly mentioned)</p>	
	<p>i) Resistance / Phase at 75⁰C a) HV b) LV</p>		
	<p>j) Dia of Copper wire used for Delta formation (The dia should be around 1.5 times that of winding wire)</p>		
13	Maximum No Load losses at normal ratio at 75 ⁰ C		
14	Maximum Load losses at normal ratio at 75 ⁰ C 11		
15	Maximum Total Losses (No load loss + Load loss) in watts, at 75° C		
	a) At 100% loading.	1140 watt	
	b) At 50% loading.	340 watt	
16	Tolerance on losses at normal ratio between HV & LV windings at 75 ⁰ C		
17	Impedance voltage at normal ratio between HV & LV windings at 75 ⁰ C		
18	Impulse test level of HV & LV windings at 1.2/50 micro second wave.		
19	<p>INULATION OF MATERIAL: Insulation material used & its thickness: a) Between core & LV b) Spacers c) Inter layer d) Between HV &LV winding e) Between phases f) End insulation</p>		
20	<p>CLEARANCE a) LV to Core (Radial) b) Between HV & LV (Radial) c) Phase to phase between HV & LV conductor</p>	<p>a) 3.5 mm (minimum) b) 11.0 mm (minimum) c) 10.0 mm (minimum)</p>	

20	<p>d) Between winding & body</p> <ul style="list-style-type: none"> i) Length wise ii) Breadth wise iii) Top cover and top most live part <p>e) End insulation</p> <p>f) Thickness of locking spacers between HV coils</p> <p>g) Axial wedges between HV & LV coils</p> <p>h) size of duct between LV & HV</p>	<p>e) 25.0 mm (minimum)</p> <p>f) 10.0 mm (minimum)</p> <p>g) 6 nos.</p>	
21	<p>TANK:</p> <p>a) Shape</p> <p>b) Thickness of tank sheets:</p> <ul style="list-style-type: none"> i) Top & bottom ii) Side walls iii) Collar <p>c) Internal dimensions of tank:</p> <ul style="list-style-type: none"> i) Length (l) ii) Breadth (b). iii) Height (h₁) (h₂) (Difference between h₁ & h₂ should be 20 mm) <p>d) Gasket used between top cover and tank</p> <ul style="list-style-type: none"> i) Material. ii) Thickness iii) Type of joint <p>e) Pulling lugs</p> <ul style="list-style-type: none"> i) No. ii) thickness iii) Position of fixing <p>f) Lifting lugs</p> <ul style="list-style-type: none"> i) No. ii) Thickness iii) Position of fixing <p>g) Reinforcement of tank sides</p>	<p>a) Rectangular</p> <p>b) Thickness of tank sheets:</p> <ul style="list-style-type: none"> i) 5.0 mm ± Tolerance as per relevant IS:1852 ii) 3.15 mm ± Tolerance as per relevant IS:1852. iii) Collar <p>d) Gaskets wherever used shall conform to Type III as per IS 11149/Type C as per IS 4253.</p> <p>e) Pulling lugs</p> <ul style="list-style-type: none"> i) 4 nos of welded heavy duty ; ii) 8 mm thick ; iii) provided on length side; <p>f) Lifting lugs</p> <ul style="list-style-type: none"> i) 2 nos welded heavy duty lifting ii) 8 mm; iii) on the side wall. <p>g) By Angle size 40x40x6 mm</p>	

22	<p>BUSHING:</p> <p>a) Characteristics :</p> <p>i) Dry Flashover Voltage- HV - LV -</p> <p>ii) Wet Flashover Voltage- HV - LV -</p> <p>iii) Impulse Flashover Voltage HV - LV -</p> <p>b) Material bushing rods</p> <p>c) Size of bushing rods</p> <p>d) Mounting on side walls or top cover</p> <p>e) Whether continuous sheet metal pocket used for mounting all three/four:</p> <p> i) HV bushings.</p> <p> ii) LV bushings.</p> <p> (Pipe are not acceptable)</p> <p>f) Bushing clearances</p> <p> i) Phase to phase: HV- LV-</p> <p> ii) Phase to earth : HV – LV –</p> <p>g) Arrangement of studs</p>		
23	<p>CONSERVATOR:</p> <p>a) Dimensions.</p> <p>b) Volume</p> <p>c) Diameter of pipe used for conservator and tank</p> <p>d) Please confirm whether pipe is projected into the conservator 20 mm above the bottom of the conservator.</p>	<p>c) inside diameter of the pipe connecting the conservator to the main tank should be 25 to 50 mm.</p> <p>d) The pipe should be projected into the conservator so that its end is at least 20 mm above the bottom of the conservator so as to create a sump for collection of impurities. The minimum oil level corresponding to 5° C should be above the sump level.</p>	

24	RADIATORS: a) Nos. of Radiator. b) No. of Radiators mounted. i) On LV side ii) On HV side c) Nos. of fins per radiator d) Size of each fin.		
25	OIL TO FILLED IN : a) Grade Characteristics. b) Transformer tank i) Volume ii) Weight c) Conservator : i) Volume ii) Weight d) Total Oil filled i) Volume ii) Weight		
26	OVERALL DIMENSION OF TRANSFORMERS: a) Length b) Breadth c) Height		
27	Engraving of Sl.No. & name of firm a) On bottom or core clamping channel b) Side of wall & top cover of tank. c) Date of dispatch on the tank.		
28	MS Plate of size 125x125 mm welded on side wall stiffener of tank with engraving of : i) Name of the firm ii) Rating iii) Serial No. iv) Order No. & date. v) Date of Despatch.		
29	Weight of Windings : a) HV b) LV.		
30	Weight of core & Winding assembly:		
31	Untanking weight if core & winding (including oil absorption)		
32	Weight of tank & fittings including radiators		
33	Weight of complete transformer including fittings & Oil		
34	Colour of Transformer	Grey and conservator white.	

35	REFERENCE OF TYPE TEST REPORTS : a) Short circuit test report No. & dt. b) Impulse test report No. & dt.		
36	Top cover and side walls of the transformer tanks should be welded with “U” clamps on four corners and centre of both length sides.		
37	Reference of BIS certificate obtained by the bidder and its validity date (Copy of the certificate to be submitted with Part – I bid)		
38	BIS logo sticker with registration no to be provided on the body of the transformer		

Signature of the Representative
of the firm with seal

Name :

Designation :

8. STANDARD RATINGS & PRINCIPAL PARAMETERS :

The Transformers shall be suitable for outdoor installation with three phase, 50 Hz, 11 kV system in which the neutral is effectively earthed and they should be suitable for service under fluctuations in supply voltage upto plus 10% to minus 15%.

Sl.	Item	Specification
1	Continuous rated capacity	63 kVA
2	System voltage (max.)	12 kV
3	Rated voltage HV	11 kV
4	Rated voltage LV	433 - 250 V
5	Line current HV	5.25 A
6	Line current LV	133.0 A
7	Frequency	50 c/s +/- 5%
8	No. of Phases	Three
9	Connection HV	Delta
10	Connection LV	Star (Neutral brought out)
11	Vector group	Dyn-11
12	Type of cooling	ONAN
13	Noise level at rated voltage and frequency	51 db

14	Permissible temperature rise over ambient (as per IS : 2026) - i) Of top oil measured by thermometer ii) Of winding measured by resistance	35 Deg.C 40 Deg.C.
15	Minimum clearances in air of bushing terminals with connectors fitted. a) HV phase to phase / phase to earth (mm) b) LV phase to phase / phase to earth (mm) c) LV phase to neutral (mm) d) LV neutral to Earth (mm)	255 / 140 75 / 40 75 55
16	No load Voltage Ratings	11000 / 433 - 250 Volts
17	Taps	No tapings shall be provided for transformer upto & i/c 100 KVA rating

9.0 FOLLOWING TENDER ENQUIRY PROFORMA SHOULD BE DULY FILLED UP BY THE INTENDING BIDDERS:-

Proforma- (I). INFORMATION TO BE FURNISHED BY THE TENDERER FOR APPRAISAL OF FIRM'S CAPABILITY & CAPACITY TO MANUFACTURE ITEM (S) EQUIPMENT AS PER REQUIREMENT TO TENDER ENQUIRY :

1	(A)	(i)	Name of the tendering Firm		
		(ii)	Complete address of the required office		
		(iii)	Telegraphic address		
		(iv)	Phone No.		
		(v)	Fax No.		
		(vi)	Email No.		
	(B)	(i)	Name of the two responsible officers of the firm with designation (Managing Director / Partner/Chief Engineer / Works Engineer etc.		
		(ii)	Day of which weekly holiday is observed.		
	©	Complete address of the works:			
		(i)	Name and Designation of the Chief Executive of the Works and his immediate junior		
		(ii)	Telephone number(s)		
		(iii)	Email No.		
		(iv)	Fax No.		
		(v)	Day on which weekly holiday is observed		
	2	Year of the Establishment :			
3	Financial Position :				

	(a).	(i)	Land (Area & Value)	
		(ii)	Building (Covered area & value)	
		(iii)	Plant & Machinery (Value in Rs. Lakh)	
		(iv)	Total drawing limit(Certificate from bankers) (Rs. Lakh)	
	(b)	Annual financial turnover (duly audited for the last three years) (Rs. Lakhs)		
	©	Latest Income Tax Clearance Certificate.		
4	Manpower : (Nos)			
	(a)	Graduate Engineer(s)		
	(b)	Diploma holder(s)		
	©	Skilled workers		
	(d)	Unskilled workers		
5	Production capacity per month of the item covered in your quotation and justification for assessment			
	(a)	Details of plant & machinery installed (please attached separate sheets, if necessary).		
	(b)	Details of raw material required		
	©	Source of raw material.		
	(d)	Stock in hand.		
	(e)	Quality controls exercised in procurement of materials.		
6	Manufacturing process & quality control:-			
	(a)	Details of manufacturing process.		
	(b)	Scheme of quality controls		
		(i)	During manufacturing process.	
		(ii)	At the finished stage	
	(iii)	Whether any record is being maintained in respect of quality controls exercised		
7	(a)	Whether items offered conforms to IS or any other internationally recognized standards, if so, give reference.		
	(b)	Whether the firm is licensed to use ISI mark or any other Govt. Quality Mark. (copies of latest test certificates issued by Govt. Laboratories / any Recognized Test House be attached.		

Proforma- (II). Details of Testing Facility :

Name of Test		Detail of testing facilities available	Remarks
1	Test of Raw Materials		
	a)		
	b)		

2	Routine Test (Using power analyzer for No Load & and Load loss Test)		
	a)		
	b)		
3	Acceptance Test		
	a)		
	b)		
4	Type Test		
	a)		
	b)		

Name of Firm
 Name & Signature of the tenderer
 Designation
 Date

Note : In case, testing facilities are not available for certain test, indicate in remarks column from which testing house(S)/institution (s) these tests will be got carried out.

Sl. No.	Name of the client and Description of order	Value of order (in Rs.)	Period of supply by the tenders against target	Name and address to whom reference may be made
1	2	3	4	5
1				
2				
3				
4				
5				

Name of Firm
 Name & Signature of the tenderer
 Designation
 Date

Proforma- (III). DETAILS OF TENDERER’S EXPERIENCE:

Tenderer shall furnish here particulars of similar orders executed / under execution by him, to whom a reference may be made by Purchaser, in case such a reference is necessary.

**Proforma-IV. Checklist for STAGE INSPECTION for DT’s
(To be furnished by the Manufacturer)**

To conduct the stage inspection it is mandatory for bidders to furnish the following information as per their technically vetted designed data base, failing to which the offer may be treated as disqualified.

1.0 CHECK LIST FOR TRANSFORMER - CORE ASSEMBLY STAGE

Check the following with reference to the core drawing.

a	Dimension of yoke clamp & insulation	
b	Height & stack of each step.	
c	Height of window dimension.	
d	Core circle & core centre dimensions	
e	Thickness of core stamping.	

NOTE:

1. Tolerances to be mentioned as per design.
2. After varnishing the assembled core send it to core testing department for no-load loss measurement before coil erection.

2.0 CHECK LIST FOR TRANSFORMER - COIL WINDING STAGE:

Refer the applicable process specification and Electrical specification:

1	The size of Winding Wire.	
2	The size, thickness and number of layers of the Insulation	
3	The Insulation scheme.	
4	The inner & outer diameter.	
5	The height of the Coil.	
6	The total height of the coil assembly before & after shrinkage.	
7	The dimensions of the inter layer duct (L.V.).	
8	Continuity between conductors of low voltage Winding.	
	Record any other general observations / comments / deviation.	

3.0. CHECK LIST FOR TRANSFORMER - CORE COIL ASSEMBLY STAGE:

1	Blow air under pressure to remove loose materials, dust etc., before tanking the transformers.	
2	The specification for drying process with reference to a. Dimensions of drying. b. Temperature of the oven.	

	c. Insulation resistance.	
3	Reference to core coil assembly drawing.	
a	Dimensions of the strip provided between core and low voltage coil and between low voltage coil and high voltage coil.	
b	Dimensions of the cylinder provided between core & low voltage coil and between low voltage coil and high voltage coil.	
c	High voltage and low voltage connections with reference to the particular connection drawings.	
d	The dimensions & clearance of all the barriers provided.	
e	The insulation resistance of coil.	
f	The various electrical clearance as per the connection drawing.	

4.0 CHECK LIST FOR TRANSFORMER FINAL ASSEMBLY STAGE:

Check for all round clearance after the core coil assembly is lowered into the tank.

a	From Higher Voltage lead to tank.	
b	From Higher Voltage winding to tank	
c	From Low Voltage connections to the tank.	
d	From Higher Voltage lead to the turret.	
e	From Tap Switch connections to the tank.	

5.0 CHECK LIST FOR TRANSFORMER - READY FOR DESPATCH:

1. Check the accessories / components with reference to General assembly drawing and packing list.
2. Check the serial number on the items dismantled with respect to the numbers given in the general assembly drawing.
3. Check gas filling equipment wherever used for operation.
4. Check oil level of equipment before despatch.

6.0 MAXIMUM FLUX DENSITY AND CORE WEIGHT CALCULATION

(To be filled in by Bidder and shall be furnished with the Technical Bid)

Step No	Width of steps [mm]	Stack Thickness [mm]	Gross Iron Area [mm ²]
1			
2			
3			
4			
5			
6			
7			
8			
9			
10			

------	--	--	--

$$B_{\max} = E / (4.44 \times f \times A_i \times N)$$

Where E = L.V. winding phase voltage / phase

f = Rated frequency = 50 HZ.

B_{\max} = Maximum flux density in Tesla.

A_i = Net iron area in sq.m = Gross iron area x stacking factor in sq.m

N = Number of L.V.winding, turns/phase

Stacking Factor = 0.97 maximum

Core weight calculation:-

Core dia [in mm] =

Window height [in mm] =

Limb center [in mm] =

Weight of core = [3 x window height + 4 x limb centre + 2 x max. width] x Net iron area x Density of core

NB: - 1 Specific loss vs. flux density graph for the type of core lamination to be used has to be furnished.

2. VA/Kg. Vs flux density graph for the core lamination to be used has to be furnished.

3. Any other factor assumed for above calculation to be explained with reasons.

N.B.:- The bidder may use its own method of calculation towards determination of maximum flux density and weight of the core. But the same shall be supported with proper explanation and justification.

Place:

Date:

with seal of Company

Signature of Tenderer

SECTION - V

PRICE BIDDING SCHEDULE

The qualified Bidder(s) / Contractor(s) should duly fill up the schedule of item(s) format. **The rate and amount are to be written both in figures and words in such a way that interpolation is not possible.** Any discrepancy noticed in quoting the amounts in words and figures, , the quoted amount in words shall be considered for evaluation and placing of orders. In case of figures, the word Rs. should be written before the figure and paise at the end(viz. Rs.250.50 p). In case of rate or amount in words, the ‘Rupees’ should precede and the ‘only’ should be written at the end (viz. Rupees Two hundred fifty and Paise fifty only).

Before quoting in PRICE BIDDING SCHEDULE, please follow the Clause no 10.1, Section –II.

Sl. No.	Description of items	Quantity	Price break up	Unit	Rate/unit (in figures)	Rate / unit (in words)	Amount (in figures)	Amount (in words)
01.	Design, Manufacture, Testing at works, Supply & Transportation i/c loading & unloading of 63 KVA, BIS certified (Energy Efficiency level -2), 11 / 0.433- 0.250 KV, 3 phase, 50 Hz, Distribution Transformer conforming to IS : 1180-2014 and IS: 2026 & other relevant IS as amended latest. N.I.T. No = ESD / 19 / 2018-'19.	120 nos.	(A). Ex-factory price : (B). G.S.T. on (A) (@.....%): (C). Freight and Insurance including Loading & Unloading at Destination. (D). G.S.T. on (C) (@.....%) (E). Total: (A+B+C+D) (Rs.....)	Rs. Rs. Rs. Rs.				
02.	Pre-despatch Inspection cost	3 (three) lots.	(F). Per person Lot-wise (as Per delivery schedule) Pre-despatch Inspection cost	Lot				
03.	Total Financial Involvement for 120 nos item			Rs.				

N.B :

- The bidders shall quote as per the schedule at SECTION-V and any deviation taken from the SIPULATED SECTION-V, their offers shall not be evaluated and rejected outright without showing any reasons thereof.

- Rate offered for Pre-despatch Inspection cost is reimbursable.

Place:
Date:
with seal of Company

Signature of Tenderer

DECLARATION

I/We hereby declare that I/We have personally gone through the Bid- Document containing general terms and conditions incorporated in the Notice Inviting Competitive Bidding for the works /supply and I/We do agree to abide by all the rules and regulations of TSECL, Agartala, Tripura.

SIGNATURE OF THE TENDERER / BIDDER

FORM OF PERFORMANCE SECURITY (GUARANTEE) Bank Guarantee

1. In consideration of the Chairman, TSECL (hereinafter called "TSECL") having offered to accept the Terms and conditions of the proposed agreement betweenand [herein after called the said Contractor(s)/supplier(s)] for the work. (herein after "the said agreement"), against L.O.A. no. , N.I.T. no having agreed to production of a irrevocable Bank Guarantee for Rs.(Rupees.only) as a security/ guarantee from the contractor(s)/ /supplier(s)for compliance of his obligations in accordance with the terms and conditions in the said agreement.

We.....(indicate the name of the Bank) (hereinafter referred to as "the Bank") hereby undertake to pay to the Chairman, TSECL an amount not Exceeding Rs(Rupees. only) on demand by TSECL .

2. We.....(Indicate the name of the Bank) do here by undertake to pay the amounts due and payable under this Guarantee without any demure, merely on a demand from TSECL stating that the amount claimed is required to meet the recoveries due or likely to be due from the said contractor(s). Any such demand made on the Bank shall be conclusive as regards the amount due and payable by the Bank under this Guarantee. However, our liability under this guarantee shall be restricted to an amount not exceeding Rs..... (Rupeesonly).

3. We, the said Bank, further undertake to pay to the Chairman, TSECL any money so demanded notwithstanding any dispute or disputes raised by the contractor(s) in any suit or proceeding pending before any court or tribunal relating thereto, our liability under this present being absolute and unequivocal.

The payment so made by us under his bond shall be a valid discharge of our liability for payment there under and the contractor(s)/supplier(s) shall have no claim against us for making such payment.

4. We.....(Indicate the name of the bank) further agree that the guarantee herein contained shall remain in full force and effect during the period that would be taken for the performance of the said agreement and that it shall continue to be enforceable till all the dues of TSECL under or by virtue of the said agreement have been fully paid and its claims satisfied or discharged or till Engineer-in-Charge/Authority –in-charge on behalf of TSECL certified that the terms and conditions of the said agreement have been fully and properly carried out by the said contractor(s) and accordingly discharges this guarantee.

5. We... ..(indicate the name of the bank) further agree with TSECL that TSECL shall have the fullest liberty without our consent and without effecting in any manner our obligations hereunder to vary any of terms and conditions of the said agreement or to extend time of performance by the said contractor(s) from time to time or to postpone for any time or from time to time any of the powers exercisable by TSECL against in the said contractor(s) and to forebear or enforce any of the terms and conditions relating to the said agreement and we shall not be relived from our liability by reason of any such variation, or extensions being granted to the said contractor(s) or for any forbearance, act of omission on the part of TSECL or any indulgence by the TSECL to the said contractor(s) or by any such matter or thing

whatsoever which under the law relating to sureties would, but for this provision ,have effect of so relieving us.

6. This guarantee will not be discharged due to the change in the constitution of the Bank or the contractor(s).

7. We.....(Indicate the name of the bank) lastly undertake not to revoke this guarantee except with the previous consent of TSECL in writing.

8. This guarantee shall be valid up to.....*..... unless extended on demand by TSECL. Notwithstanding anything mentioned above, our liability against this guarantee is restricted to Rs.....(Rupees. only) and unless a claim in writing is lodged within six months of the date of expiry or the extended date of expiry of this guarantee all our liabilities under this guarantee shall stand discharged.

In presence of:
WITNESS

Dated this..... Day of.....
for and on behalf of (The Bank)

1
2

Signature-----

Name & Designation -----

Authorisation No.
Name & Place

The above Guarantee is accepted by TRIPURA STATE ELECTRICITY CORPORATION LTD.

For and on behalf of behalf of TRIPURA STATE ELECTRICITY CORPORATION LTD

Signature;-----

Name:-----

Designation:-----

Dated:-----

Note: * Date of validity should be schedule date of completion + Six months.

xxxxx

APPLICATION FOR EXTENSION OF TIME

(Part – I)

1. Name of Contractor _____
2. Name of work (as given in the contract) _____

3. Agreement no. _____
4. Contract amount _____
5. Date of Commencement of work as per agreement _____
6. Period allowed for completion of work (as per agreement) _____
7. Date of completion stipulated in the agreement _____
8. Actual date of completion _____
9. Period for which extension of time has been given previously if any _____
 - a) 1st extension vide No. _____
 - b) 2nd extension vide No. _____
 - c) 3rd extension vide No. _____
 - d) 4th extension vide No. _____
10. Period for which extension have been previously given (Copies of the previous application should be attached).
11. Hindrances on account of which extension is applied for with date on which hindrances occurred.

Sl. No.	Nature of hindrances	Date of occurrence	Period of which hindrance is likely to last	Extension of time applied for by the contract or	Overlapping period, if any, giving reference to items which overlap	Period for which extension is applied for.	Remarks as to why the hindrances occurred and justification for extension of time

12. Total period for which extension is now applied for on account of hindrances mentioned above.
13. Extension of time required for extra work: - _____ Months. _____ days.
14. Detailed for extra work and the amount involved: -

15.

- a) Total value of extra work: -
- b) Proportionate period of extension of time based on estimated amount put to tender on account of extra work: -

16. Total extension of time required for 11 & 12: -

Signature of Contractor

XXXX

APPLICATION FOR EXTENSION OF TIME

(Part – II)

(To be filled in by TSECL)

1. Date of receipt of application from _____ contractor for the work of _____ in the Sub-Divisional _____.
2. Acknowledgement issued by the Sr. Manager, vide his No. _____ Dated _____.
3. Recommendation of Sr. Manager, in – charge of the Sub-Division is to whether the reasons given by the Contractor are correct and what extension, if any, recommended by him, if he does not recommended the extension, reasons for rejection should be given

Dated

Signature of the Sr. Manager in-charge.

XXXX

APPLICATION FOR EXTENSION OF TIME

(Part – III)

(To be filled in by TSECL)

1. Date of receipt in the Divisional office: _____
2. Report of DGM, in-charge of the Division regarding hindrances mentioned by the contractor _____

Sl. No.	Nature of hindrances	Date of occurrence	Period for which hindrances is likely to last	Extension of time applied for by the contractor	Overlapping period, if any, giving reference to items which overlap	Net extension applied for	Remarks as to why the hindrances occurred and justification for extension recommended

3. Recommendation / Approval of the DGM, in-charge of the Division: -
(The present progress of work should be stated and whether the work is likely to be completed by the date upto which extension is applied for, if extension of time is not recommended, what compensation is proposed to be levied under clause 13 of section - III.

Signature of DGM

4. Recommendation / Approval of the AGM, in-charge of the Circle: -

Signature of AGM

5. Recommendation / Approval of the GM (Technical): -

Signature of GM (Technical)

6. Recommendation / Approval of the CMD: -

Signature of CMD

XXXX

(N.J. Stamp of Rs.30/-)
BEFORE THE NOTARY
: TRIPURA.
INDEMNITY BOND

THIS INDEMNITY BOND IS EXECUTED ON THE _____ DAY OF _____
 2010 A. D. By Shri _____,
 S/O. Shri / Late _____, Vill. _____
 P.S. _____, District _____, aged about _____ years, a citizen of India
 (Here-in-after called the Contractor indemnifier) in favour of Tripura State Electricity Corporation Ltd.
 (TSECL) (Here-in-after called the Corporation) under the terms and conditions here-in-after mentioned
 :-

WHEREAS, I am a Class __ Government Contractor and the Corporation awarded me to execute the
 work namely

I agree to indemnify the corporation that in the event of any accident of any workman, arising out of
 and in course of employment, during execution of the work I shall be liable to pay full compensation to
 the workmen employed by me for execution of the work.

I also agree to indemnify and save harmless the corporation that, the lives & bodies of my workmen(s),
 employed by me for execution of this work, are duly insured with the
 _____ Insurance Company _____
 Branch under Act / Scheme.

I further agree to indemnify and save harmless the corporation that the corporation or any of its
 Director (s) or Officer(s) or Manager(s) shall not be made liable to pay any compensation to any
 workmen in the event of death or bodily injury, arising out of the in course of employment under me,
 employed by me for execution of the work namely

IN WITNESS WHERE OF I SIGN THIS INDEMNITY BOND TODAY, THE DAY, MONTH, YEAR
 FIRST ABOVE WRITTEN IN PRESENCE OF FOLLOWING WITNESSES.

Witnesses 1. 2. Identified by me _____ Advocate	_____ Full Signature of Contractor (INDEMNIFIER)
--	--

(Bidder's Letter Head)

XXXX

**PROFORMA FOR EVIDENCE OF ACCESS TO OR AVAILABILITY OF CREDIT/FACILITIES
(TO BE GIVEN BY BANKER OF BIDDER)**

BANK CERTIFICATE

This is to certify that M/s..... (FULL NAME AND ADDRESS) who are submitting their Bid toagainst their tender specification vide Ref. No..... and dateis our customer for the pastyears.

Their financial transactions with our bank have been satisfactory. They enjoy the following fund based and non fund based limits including guarantees, L/C and other credit facilities with us against which the extent of utilization as on date is also indicated below:

Sl.No.	TYPE OF FACILITY	SANCTIONED LIMIT AS ON DATE	UTILIZATION AS ON DATE.....

This letter is issued at the request of M/s.....

Sd/-

Name of Bank.....

Name of authorized Signatory.....

Designation.....

Phone No.....

Address.....

SEAL OF THE BANK

xxxxxx